

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-05

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵(4#)		管桩型号	实际桩顶标高(M)	使用桩长(M)	有效桩长(M)	最后贯入度(MM)	备注
序号	桩号						
114	246	PHC300AB70-8.0	13.19	8	8	27	
115	247	PHC300AB70-8.0	13.18	8	8	27	
116	248	PHC300AB70-8.0	13.22	8	8	30	
117	214	PHC300AB70-8.0	13.18	8	8	27	
118	215	PHC300AB70-8.0	13.23	8	8	27	
119	422	PHC300AB70-8.0	13.20	8	8	32	
120	423	PHC300AB70-8.0	13.18	8	8	27	
121	424	PHC300AB70-8.0	13.17	8	8	27	
122	425	PHC300AB70-8.0	13.25	8	8	27	
123	426	PHC300AB70-8.0	13.21	8	8	27	
124	427	PHC300AB70-8.0	13.22	8	8	28	
125	428	PHC300AB70-8.0	13.21	8	8	27	
126	429	PHC300AB70-8.0	13.24	8	8	27	
127	430	PHC300AB70-8.0	13.22	8	8	27	
128	431	PHC300AB70-8.0	13.24	8	8	24	
129	432	PHC300AB70-8.0	13.21	8	8	27	
130	433	PHC300AB70-8.0	13.25	8	8	27	
131	434	PHC300AB70-8.0	13.22	8	8	26	
132	435	PHC300AB70-8.0	13.23	8	8	27	
133	461	PHC300AB70-8.0	13.22	8	8	29	
134	462	PHC300AB70-8.0	13.20	8	8	27	
135	463	PHC300AB70-8.0	13.24	8	8	25	
136	464	PHC300AB70-8.0	13.24	8	8	27	
137	465	PHC300AB70-8.0	13.22	8	8	27	
138	466	PHC300AB70-8.0	13.21	8	8	26	
139	467	PHC300AB70-8.0	13.19	8	8	27	
140	468	PHC300AB70-8.0	13.20	8	8	29	
141	469	PHC300AB70-8.0	13.23	8	8	27	
142	470	PHC300AB70-8.0	13.22	8	8	27	
143	471	PHC300AB70-8.0	13.22	8	8	28	
144	472	PHC300AB70-8.0	13.23	8	8	27	
145	473	PHC300AB70-8.0	13.24	8	8	27	
146	474	PHC300AB70-8.0	13.23	8	8	30	
147	475	PHC300AB70-8.0	13.24	8	8	27	
148	501	PHC300AB70-8.0	13.22	8	8	27	
149	502	PHC300AB70-8.0	13.22	8	8	32	
150	503	PHC300AB70-8.0	13.22	8	8	27	
151	504	PHC300AB70-8.0	13.23	8	8	27	
152	505	PHC300AB70-8.0	13.20	8	8	27	
153	506	PHC300AB70-8.0	13.23	8	8	27	
154	507	PHC300AB70-8.0	13.20	8	8	28	
155	508	PHC300AB70-8.0	13.23	8	8	27	
156	509	PHC300AB70-8.0	13.20	8	8	27	
157	510	PHC300AB70-8.0	13.23	8	8	27	
158	511	PHC300AB70-8.0	13.20	8	8	24	

旁站监理: 王兴明

质检员: 姜佳正

施工日期: 20170317