

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-06

工程名称		通威渔光一体(东港)现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵(4#)		管桩型号	实际桩顶标高(M)	使用桩长(M)	有效桩长(M)	最后贯入度(MM)	备注
序号	桩号						
159	306	PHC400A95-11.0	13.20	11	11	27	
160	307	PHC400A95-11.0	13.23	11	11	27	
161	308	PHC400A95-11.0	13.23	11	11	26	
162	309	PHC400A95-11.0	13.20	11	11	27	
163	310	PHC400A95-11.0	13.22	11	11	29	
164	311	PHC400A95-11.0	13.22	11	11	27	
165	312	PHC400A95-11.0	13.18	11	11	27	
166	313	PHC400A95-11.0	13.22	11	11	28	
167	314	PHC400A95-11.0	13.18	11	11	27	
168	315	PHC400A95-11.0	13.23	11	11	27	
169	341	PHC400A95-11.0	13.22	11	11	30	
170	342	PHC400A95-11.0	13.18	11	11	27	
171	343	PHC400A95-11.0	13.17	11	11	27	
172	344	PHC400A95-11.0	13.23	11	11	32	
173	345	PHC400A95-11.0	13.21	11	11	27	
174	346	PHC400A95-11.0	13.23	11	11	27	
175	347	PHC400A95-11.0	13.21	11	11	27	
176	348	PHC400A95-11.0	13.22	11	11	27	
177	349	PHC400A95-11.0	13.22	11	11	28	
178	350	PHC400A95-11.0	13.24	11	11	27	
179	376	PHC400A95-11.0	13.23	11	11	27	
180	377	PHC400A95-11.0	13.25	11	11	27	
181	378	PHC400A95-11.0	13.22	11	11	24	
182	379	PHC400A95-11.0	13.25	11	11	27	
183	380	PHC400A95-11.0	13.22	11	11	27	
184	381	PHC400A95-11.0	13.20	11	11	27	
185	382	PHC400A95-11.0	13.22	11	11	26	
186	383	PHC400A95-11.0	13.24	11	11	27	
187	384	PHC400A95-11.0	13.22	11	11	29	
188	385	PHC400A95-11.0	13.24	11	11	27	
189	411	PHC400A95-11.0	13.23	11	11	27	
190	412	PHC400A95-11.0	13.25	11	11	28	
191	413	PHC400A95-11.0	13.23	11	11	27	
192	414	PHC400A95-11.0	13.21	11	11	27	
193	415	PHC400A95-11.0	13.22	11	11	30	
194	416	PHC400A95-11.0	13.19	11	11	27	
195	417	PHC400A95-11.0	13.22	11	11	27	
196	418	PHC400A95-11.0	13.23	11	11	32	
197	419	PHC400A95-11.0	13.18	11	11	27	

旁站监理: 王兴明

质检员: 李伟正

施工日期: 20170317