

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-08

工程名称		通威渔光一体(东港)现代渔业产业园一期20MWp光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵(4#)		管桩型号	实际桩顶标高(M)	使用桩长(M)	有效桩长(M)	最后贯入度(MM)	备注
序号	桩号						
234	31	PHC400A95-11.0	13.19	11	11	27	
235	32	PHC400A95-11.0	13.22	11	11	28	
236	33	PHC400A95-11.0	13.21	11	11	27	
237	34	PHC400A95-11.0	13.23	11	11	27	
238	35	PHC400A95-11.0	13.21	11	11	27	
239	36	PHC400A95-11.0	13.18	11	11	24	
240	37	PHC400A95-11.0	13.17	11	11	27	
241	38	PHC400A95-11.0	13.21	11	11	30	
242	39	PHC400A95-11.0	13.21	11	11	28	
243	40	PHC400A95-11.0	13.23	11	11	27	
244	71	PHC400A95-11.0	13.21	11	11	27	
245	72	PHC400A95-11.0	13.24	11	11	30	
246	73	PHC400A95-11.0	13.22	11	11	27	
247	74	PHC400A95-11.0	13.24	11	11	27	
248	75	PHC400A95-11.0	13.23	11	11	32	
249	76	PHC400A95-11.0	13.19	11	11	27	
250	77	PHC400A95-11.0	13.22	11	11	27	
251	78	PHC400A95-11.0	13.21	11	11	27	
252	79	PHC400A95-11.0	13.23	11	11	27	
253	80	PHC400A95-11.0	13.21	11	11	28	
254	111	PHC400A95-11.0	13.18	11	11	27	
255	112	PHC400A95-11.0	13.19	11	11	27	
256	113	PHC400A95-11.0	13.22	11	11	27	
257	114	PHC400A95-11.0	13.21	11	11	24	
258	115	PHC400A95-11.0	13.23	11	11	27	
259	116	PHC400A95-11.0	13.21	11	11	30	
260	117	PHC400A95-11.0	13.18	11	11	28	
261	118	PHC400A95-11.0	13.17	11	11	27	
262	119	PHC400A95-11.0	13.21	11	11	27	
263	120	PHC400A95-11.0	13.21	11	11	30	
264	151	PHC400A95-11.0	13.23	11	11	27	
265	152	PHC400A95-11.0	13.21	11	11	27	
266	153	PHC400A95-11.0	13.24	11	11	32	
267	154	PHC400A95-11.0	13.22	11	11	27	
268	155	PHC400A95-11.0	13.24	11	11	27	
269	156	PHC400A95-11.0	13.23	11	11	27	
270	157	PHC400A95-11.0	13.19	11	11	27	
271	158	PHC400A95-11.0	13.22	11	11	28	
272	159	PHC400A95-11.0	13.21	11	11	27	
273	160	PHC400A95-11.0	13.23	11	11	27	

旁站监理:

王兴明

质检员:

姜健正

施工日期: 20170318