

混凝土预制桩施工监理旁站记录

编号: GFDZJDM30-GFQ-06

工程名称		通威渔光一体(东港)现代渔业产业园一期20MWp光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵(1#)		管桩型号	实际桩顶标高(M)	使用桩长(M)	有效桩长(M)	最后贯入度(MM)	备注
序号	桩号						
186	133	PHC300AB70	13.24	8	8	29	
187	76	PHC300AB70	13.22	8	8	23	
188	50	PHC300AB70	13.24	8	8	30	
189	49	PHC300AB70	13.23	8	8	28	
190	77	PHC300AB70	13.25	8	8	29	
191	132	PHC300AB70	13.23	8	8	30	
192	161	PHC300AB70	13.21	8	8	28	
193	216	PHC300AB70	13.22	8	8	28	
194	245	PHC300AB70	13.19	8	8	29	
195	295	PHC300AB70	13.22	8	8	27	
196	324	PHC300AB70	13.23	8	8	23	
197	369	PHC300AB70	13.18	8	8	26	
198	398	PHC300AB70	13.23	8	8	25	
199	448	PHC300AB70	13.24	8	8	27	
200	477	PHC300AB70	13.23	8	8	30	
201	532	PHC300AB70	13.19	8	8	25	
202	562	PHC300AB70	13.23	8	8	25	
203	617	PHC300AB70	13.20	8	8	29	
204	646	PHC300AB70	13.19	8	8	25	
205	647	PHC300AB70	13.23	8	8	28	
206	616	PHC300AB70	13.23	8	8	28	
207	563	PHC300AB70	13.19	8	8	28	
208	531	PHC300AB70	13.22	8	8	26	
209	478	PHC300AB70	13.22	8	8	25	
210	447	PHC300AB70	13.19	8	8	28	
211	399	PHC300AB70	13.22	8	8	25	
212	368	PHC300AB70	13.20	8	8	28	
213	325	PHC300AB70	13.23	8	8	27	
214	294	PHC300AB70	13.20	8	8	24	
215	246	PHC300AB70	13.18	8	8	24	
216	215	PHC300AB70	13.17	8	8	29	
217	162	PHC300AB70	13.20	8	8	22	
218	131	PHC300AB70	13.21	8	8	25	
219	78	PHC300AB70	13.23	8	8	25	
220	48	PHC300AB70	13.21	8	8	24	
221	47	PHC300AB70	13.24	8	8	25	
222	79	PHC300AB70	13.22	8	8	25	
223	130	PHC300AB70	13.24	8	8	23	
224	163	PHC300AB70	13.24	8	8	29	
225	214	PHC300AB70	13.25	8	8	25	
226	247	PHC300AB70	13.25	8	8	27	
227	293	PHC300AB70	13.25	8	8	27	
228	326	PHC300AB70	13.23	8	8	25	
229	367	PHC300AB70	13.20	8	8	29	
230	400	PHC300AB70	13.22	8	8	25	

旁站监理: 王兴明 姜俊正

施工日期: 20170226