

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-09

工程名称		通威渔光一体(东港)现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵 (1#)		管桩型号	实际桩顶标高 (M)	使用桩长 (M)	有效桩长 (M)	最后贯入度 (MM)	备注
序号	桩号						
321	85	PHC300AB70	13.23	8	8	24	
322	124	PHC300AB70	13.30	8	7.9	23	高出 100
323	169	PHC300AB70	13.23	8	8	28	
324	208	PHC300AB70	13.23	8	8	29	
325	253	PHC300AB70	13.25	8	8	29	
326	287	PHC300AB70	13.22	8	8	23	
327	332	PHC300AB70	13.22	8	8	29	
328	361	PHC300AB70	13.23	8	8	29	
329	406	PHC300AB70	13.20	8	8	29	
330	440	PHC300AB70	13.22	8	8	28	
331	485	PHC300AB70	13.24	8	8	30	
332	524	PHC300AB70	13.19	8	8	26	
333	570	PHC300AB70	13.23	8	8	28	
334	609	PHC300AB70	13.22	8	8	27	
335	654	PHC300AB70	13.24	8	8	29	
336	693	PHC300AB70	13.50	8	7.7	25	高出 300
337	692	PHC300AB70	13.50	8	7.7	27	高出 300
338	655	PHC300AB70	13.22	8	8	24	
339	608	PHC300AB70	13.19	8	8	28	
340	571	PHC300AB70	13.21	8	8	28	
341	523	PHC300AB70	13.22	8	8	29	
342	486	PHC300AB70	13.19	8	8	26	
343	439	PHC300AB70	13.21	8	8	26	
344	407	PHC300AB70	13.23	8	8	25	
345	360	PHC300AB70	13.25	8	8	24	
346	333	PHC300AB70	13.24	8	8	29	
347	286	PHC300AB70	13.22	8	8	25	
348	254	PHC300AB70	13.23	8	8	29	
349	207	PHC300AB70	13.23	8	8	24	
350	170	PHC300AB70	13.19	8	8	24	
351	123	PHC300AB70	13.17	8	8	29	
352	86	PHC300AB70	13.18	8	8	27	
353	40	PHC300AB70	13.22	8	8	24	
354	3	PHC300AB70	13.23	8	8	25	
355	4	PHC300AB70	13.21	8	8	24	
356	39	PHC300AB70	13.19	8	8	24	
357	87	PHC300AB70	13.22	8	8	25	
358	122	PHC300AB70	13.24	8	8	23	
359	171	PHC300AB70	13.23	8	8	24	
360	206	PHC300AB70	13.19	8	8	25	
361	255	PHC300AB70	13.25	8	8	27	
362	285	PHC300AB70	13.24	8	8	24	
363	334	PHC300AB70	13.21	8	8	25	
364	359	PHC300AB70	13.24	8	8	29	
365	408	PHC300AB70	13.21	8	8	24	

旁站监理:

王志明

李俊正

施工日期: 20170227