

## 混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-15

| 工程名称     |     | 通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目 |           | 施工单位    |         | 特变电工新疆新能源股份有限公司 |    |
|----------|-----|----------------------------------|-----------|---------|---------|-----------------|----|
| 桩机类型     |     | 高频锤                              |           | 设计桩顶标高  |         | 13.20M          |    |
| 方阵（ 1# ） |     | 管桩型号                             | 实际桩顶标高（M） | 使用桩长（M） | 有效桩长（M） | 最后贯入度（MM）       | 备注 |
| 序号       | 桩号  |                                  |           |         |         |                 |    |
| 566      | 347 | PHC300A70                        | 13.22     | 7       | 7       | 29              |    |
| 567      | 346 | PHC300A70                        | 13.20     | 7       | 7       | 23              |    |
| 568      | 273 | PHC300A70                        | 13.21     | 7       | 7       | 24              |    |
| 569      | 267 | PHC300A70                        | 13.24     | 7       | 7       | 26              |    |
| 570      | 194 | PHC300A70                        | 13.25     | 7       | 7       | 29              |    |
| 571      | 183 | PHC300A70                        | 13.22     | 7       | 7       | 23              |    |
| 572      | 110 | PHC300A70                        | 13.23     | 7       | 7       | 30              |    |
| 573      | 99  | PHC300A70                        | 13.21     | 7       | 7       | 29              |    |
| 574      | 27  | PHC300A70                        | 13.20     | 7       | 7       | 25              |    |
| 575      | 16  | PHC300A70                        | 13.18     | 7       | 7       | 28              |    |
| 576      | 17  | PHC300A70                        | 13.22     | 7       | 7       | 30              |    |
| 577      | 26  | PHC300A70                        | 13.19     | 7       | 7       | 25              |    |
| 578      | 100 | PHC300A70                        | 13.23     | 7       | 7       | 29              |    |
| 579      | 109 | PHC300A70                        | 13.20     | 7       | 7       | 27              |    |
| 580      | 184 | PHC300A70                        | 13.22     | 7       | 7       | 29              |    |
| 581      | 193 | PHC300A70                        | 13.23     | 7       | 7       | 26              |    |
| 582      | 268 | PHC300A70                        | 13.22     | 7       | 7       | 28              |    |
| 583      | 269 | PHC300A70                        | 13.20     | 7       | 7       | 24              |    |
| 584      | 192 | PHC300A70                        | 13.19     | 7       | 7       | 25              |    |
| 585      | 185 | PHC300A70                        | 13.22     | 7       | 7       | 29              |    |
| 586      | 108 | PHC300A70                        | 13.22     | 7       | 7       | 30              |    |
| 587      | 101 | PHC300A70                        | 13.19     | 7       | 7       | 26              |    |
| 588      | 25  | PHC300A70                        | 13.20     | 7       | 7       | 29              |    |
| 589      | 18  | PHC300A70                        | 13.23     | 7       | 7       | 25              |    |
| 590      | 19  | PHC300A70                        | 13.25     | 7       | 7       | 29              |    |
| 591      | 24  | PHC300A70                        | 13.25     | 7       | 7       | 29              |    |
| 592      | 102 | PHC300A70                        | 13.23     | 7       | 7       | 25              |    |
| 593      | 107 | PHC300A70                        | 13.22     | 7       | 7       | 29              |    |
| 594      | 186 | PHC300A70                        | 13.24     | 7       | 7       | 23              |    |
| 595      | 191 | PHC300A70                        | 13.22     | 7       | 7       | 24              |    |
| 596      | 270 | PHC300A70                        | 13.18     | 7       | 7       | 29              |    |
| 597      | 271 | PHC300A70                        | 13.19     | 7       | 7       | 29              |    |
| 598      | 190 | PHC300A70                        | 13.22     | 7       | 7       | 25              |    |
| 599      | 187 | PHC300A70                        | 13.23     | 7       | 7       | 28              |    |
| 600      | 106 | PHC300A70                        | 13.22     | 7       | 7       | 27              |    |
| 601      | 103 | PHC300A70                        | 13.19     | 7       | 7       | 24              |    |
| 602      | 23  | PHC300A70                        | 13.24     | 7       | 7       | 28              |    |
| 603      | 20  | PHC300A70                        | 13.24     | 7       | 7       | 23              |    |
| 604      | 21  | PHC300A70                        | 13.24     | 7       | 7       | 29              |    |
| 605      | 22  | PHC300A70                        | 13.19     | 7       | 7       | 25              |    |
| 606      | 104 | PHC300A70                        | 13.22     | 7       | 7       | 25              |    |
| 607      | 105 | PHC300A70                        | 13.25     | 7       | 7       | 24              |    |
| 608      | 188 | PHC300A70                        | 13.23     | 7       | 7       | 25              |    |
| 609      | 189 | PHC300A70                        | 13.25     | 7       | 7       | 30              |    |
| 610      | 272 | PHC300A70                        | 13.23     | 7       | 7       | 29              |    |

旁站监理:

王云

李俊正

施工日期: 20170301