

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-04

工程名称		通威渔光一体(东港)现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵 (2#)		管桩型号	实际桩顶标高 (M)	使用桩长 (M)	有效桩长 (M)	最后贯入度 (MM)	备注
序号	桩号						
136	511	PHC300AB70	13.24	8	8	25	
137	510	PHC300AB70	13.22	8	8	27	
138	509	PHC300AB70	13.21	8	8	28	
139	508	PHC300AB70	13.19	8	8	29	
140	507	PHC300AB70	13.20	8	8	28	
141	506	PHC300AB70	13.23	8	8	29	
142	505	PHC300AB70	13.22	8	8	29	
143	504	PHC300AB70	13.22	8	8	30	
144	503	PHC300AB70	13.23	8	8	28	
145	502	PHC300AB70	13.24	8	8	27	
146	469	PHC300AB70	13.23	8	8	30	
147	468	PHC300AB70	13.24	8	8	26	
148	467	PHC300AB70	13.22	8	8	28	
149	466	PHC300AB70	13.22	8	8	29	
150	465	PHC300AB70	13.22	8	8	27	
151	464	PHC300AB70	13.23	8	8	29	
152	463	PHC300AB70	13.20	8	8	26	
153	462	PHC300AB70	13.23	8	8	25	
154	461	PHC300AB70	13.20	8	8	27	
155	460	PHC300AB70	13.23	8	8	22	
156	458	PHC300AB70	13.20	8	8	25	
157	457	PHC300AB70	13.23	8	8	25	
158	456	PHC300AB70	13.20	8	8	24	
159	455	PHC300AB70	13.20	8	8	25	
160	454	PHC300AB70	13.23	8	8	28	
161	443	PHC300AB70	13.23	8	8	25	
162	442	PHC300AB70	13.20	8	8	28	
163	441	PHC300AB70	13.22	8	8	26	
164	440	PHC300AB70	13.22	8	8	29	
165	439	PHC300AB70	13.18	8	8	28	
166	437	PHC300AB70	13.22	8	8	25	
167	436	PHC300AB70	13.18	8	8	27	
168	435	PHC300AB70	13.23	8	8	27	
169	434	PHC300AB70	13.22	8	8	28	
170	433	PHC300AB70	13.18	8	8	24	
171	432	PHC300AB70	13.17	8	8	24	
172	431	PHC300AB70	13.23	8	8	22	
173	430	PHC300AB70	13.21	8	8	26	
174	429	PHC300AB70	13.23	8	8	25	
175	428	PHC300AB70	13.21	8	8	23	
176	395	PHC300AB70	13.22	8	8	25	
177	394	PHC300AB70	13.22	8	8	25	
178	393	PHC300AB70	13.24	8	8	23	
179	392	PHC300AB70	13.23	8	8	28	
180	391	PHC300AB70	13.25	8	8	25	

旁站监理:

王宏明

姜俊正

施工日期: 20170302