

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-06

工程名称		通威渔光一体(东港)现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵(2#)		管桩型号	实际桩顶标高(M)	使用桩长(M)	有效桩长(M)	最后贯入度(MM)	备注
序号	桩号						
201	358	PHC300AB70	13.19	8	8	25	
202	357	PHC300AB70	13.23	8	8	25	
203	356	PHC300AB70	13.20	8	8	29	
204	355	PHC300AB70	13.19	8	8	25	
205	354	PHC300AB70	13.23	8	8	28	
206	331	PHC300AB70	13.23	8	8	28	
207	330	PHC300AB70	13.19	8	8	28	
208	329	PHC300AB70	13.22	8	8	26	
209	328	PHC300AB70	13.22	8	8	25	
210	327	PHC300AB70	13.19	8	8	28	
211	326	PHC300AB70	13.22	8	8	25	
212	325	PHC300AB70	13.20	8	8	28	
213	324	PHC300AB70	13.23	8	8	27	
214	323	PHC300AB70	13.20	8	8	24	
215	322	PHC300AB70	13.18	8	8	24	
216	320	PHC300AB70	13.17	8	8	29	
217	319	PHC300AB70	13.20	8	8	22	
218	318	PHC300AB70	13.21	8	8	25	
219	317	PHC300AB70	13.23	8	8	25	
220	316	PHC300AB70	13.21	8	8	24	
221	310	PHC300AB70	13.24	8	8	25	
222	309	PHC300AB70	13.22	8	8	25	
223	308	PHC300AB70	13.24	8	8	23	
224	307	PHC300AB70	13.24	8	8	29	
225	306	PHC300AB70	13.25	8	8	25	
226	304	PHC300AB70	13.25	8	8	27	
227	303	PHC300AB70	13.25	8	8	27	
228	302	PHC300AB70	13.23	8	8	25	
229	301	PHC300AB70	13.20	8	8	29	
230	300	PHC300AB70	13.22	8	8	25	
231	299	PHC300AB70	13.24	8	8	30	
232	298	PHC300AB70	13.21	8	8	23	
233	297	PHC300AB70	13.24	8	8	29	
234	296	PHC300AB70	13.23	8	8	28	
235	295	PHC300AB70	13.25	8	8	29	
236	272	PHC300AB70	13.23	8	8	29	
237	271	PHC300AB70	13.22	8	8	28	
238	270	PHC300AB70	13.22	8	8	29	
239	269	PHC300AB70	13.19	8	8	29	
240	268	PHC300AB70	13.22	8	8	28	
241	267	PHC300AB70	13.21	8	8	23	
242	266	PHC300AB70	13.18	8	8	26	
243	265	PHC300AB70	13.23	8	8	28	
244	264	PHC300AB70	13.21	8	8	27	
245	263	PHC300AB70	13.23	8	8	29	

旁站监理:

王兴明

姜建正

施工日期: 20170303