

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-08

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 2# ）		管桩型号	实际桩顶 标高（M）	使用桩长 （M）	有效桩长 （M）	最后贯入 度（MM）	备注
序号	桩号						
291	181	PHC300AB70	13.22	8	8	25	
292	180	PHC300AB70	13.23	8	8	29	
293	179	PHC300AB70	13.20	8	8	24	
294	178	PHC300AB70	13.19	8	8	28	
295	177	PHC300AB70	13.21	8	8	28	
296	144	PHC300AB70	13.20	8	8	29	
297	143	PHC300AB70	13.19	8	8	24	4根桩 产生环裂
298	142	PHC300AB70	13.21	8	8	26	
299	141	PHC300AB70	13.22	8	8	25	
300	140	PHC300AB70	13.25	8	8	24	
301	139	PHC300AB70	13.22	8	8	29	
302	138	PHC300AB70	13.22	8	8	24	
303	137	PHC300AB70	13.23	8	8	29	
304	136	PHC300AB70	13.21	8	8	24	
305	135	PHC300AB70	13.19	8	8	24	
306	133	PHC300AB70	13.17	8	8	29	
307	132	PHC300AB70	13.21	8	8	26	
308	131	PHC300AB70	13.22	8	8	24	
309	130	PHC300AB70	13.23	8	8	25	
310	129	PHC300AB70	13.21	8	8	24	
311	128	PHC300AB70	13.21	8	8	24	
312	127	PHC300AB70	13.22	8	8	25	
313	126	PHC300AB70	13.24	8	8	23	
314	125	PHC300AB70	13.23	8	8	24	
315	124	PHC300AB70	13.21	8	8	24	
316	122	PHC300AB70	13.25	8	8	27	
317	121	PHC300AB70	13.23	8	8	24	
318	120	PHC300AB70	13.21	8	8	25	
319	119	PHC300AB70	13.20	8	8	29	
320	118	PHC300AB70	13.21	8	8	24	
321	117	PHC300AB70	13.23	8	8	24	
322	116	PHC300AB70	13.30	8	8	23	
323	115	PHC300AB70	13.23	8	8	28	
324	114	PHC300AB70	13.23	8	8	29	
325	113	PHC300AB70	13.25	8	8	29	
326	80	PHC300AB70	13.22	8	8	23	
327	79	PHC300AB70	13.22	8	8	29	
328	78	PHC300AB70	13.23	8	8	29	
329	77	PHC300AB70	13.20	8	8	29	
330	76	PHC300AB70	13.22	8	8	28	
331	75	PHC300AB70	13.24	8	8	30	
332	74	PHC300AB70	13.19	8	8	26	
333	73	PHC300AB70	13.23	8	8	28	
334	72	PHC300AB70	13.22	8	8	27	
335	71	PHC300AB70	13.24	8	8	29	

旁站监理:

王岩明

姜健正

施工日期: 20170303