

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-05

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（5#）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
161	97	PHC300AB70	13.22	8	8	27	
162	96	PHC300AB70	13.25	8	8	27	
163	95	PHC300AB70	13.22	8	8	28	
164	94	PHC300AB70	13.20	8	8	29	
165	93	PHC300AB70	13.22	8	8	23	
166	92	PHC300AB70	13.24	8	8	29	
167	91	PHC300AB70	13.22	8	8	23	
168	90	PHC300AB70	13.24	8	8	30	
169	89	PHC300AB70	13.23	8	8	28	
170	88	PHC300AB70	13.25	8	8	29	
171	87	PHC300AB70	13.23	8	8	30	
172	86	PHC300AB70	13.21	8	8	28	
173	85	PHC300AB70	13.22	8	8	28	
174	84	PHC300AB70	13.19	8	8	29	
175	83	PHC300AB70	13.22	8	8	27	
176	82	PHC300AB70	13.23	8	8	23	
177	81	PHC300AB70	13.18	8	8	26	
178	80	PHC300AB70	13.23	8	8	25	
179	79	PHC300AB70	13.24	8	8	27	
180	78	PHC300AB70	13.23	8	8	30	
181	77	PHC300AB70	13.19	8	8	25	
182	76	PHC300AB70	13.23	8	8	25	
183	75	PHC300AB70	13.20	8	8	29	
184	74	PHC300AB70	13.19	8	8	25	
185	73	PHC300AB70	13.23	8	8	28	
186	72	PHC300AB70	13.23	8	8	28	
187	71	PHC300AB70	13.19	8	8	28	
188	70	PHC300AB70	13.22	8	8	26	
189	69	PHC300AB70	13.22	8	8	25	
190	68	PHC300AB70	13.19	8	8	28	
191	67	PHC300AB70	13.22	8	8	25	
192	66	PHC300AB70	13.20	8	8	28	
193	65	PHC300AB70	13.23	8	8	27	
194	64	PHC300AB70	13.20	8	8	24	
195	63	PHC300AB70	13.18	8	8	24	
196	62	PHC300AB70	13.17	8	8	29	
197	61	PHC300AB70	13.20	8	8	22	
198	60	PHC300AB70	13.21	8	8	25	
199	59	PHC300AB70	13.23	8	8	25	
200	58	PHC300AB70	13.21	8	8	24	
201	56	PHC300AB70	13.24	8	8	25	
202	55	PHC300AB70	13.22	8	8	25	
203	54	PHC300AB70	13.24	8	8	23	
204	53	PHC300AB70	13.24	8	8	29	
205	52	PHC300AB70	13.25	8	8	25	

旁站监理:

王云明

质检员:

姜臣正

施工日期: 20170307