

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-07

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 5# ）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
251	591	PHC300AB70	13.25	8	8	27	
252	590	PHC300AB70	13.23	8	8	29	
253	589	PHC300AB70	13.23	8	8	25	
254	587	PHC300AB70	13.20	8	8	29	
255	586	PHC300AB70	13.20	8	8	28	
256	585	PHC300AB70	13.22	8	8	29	
257	584	PHC300AB70	13.21	8	8	23	
258	583	PHC300AB70	13.22	8	8	28	
259	582	PHC300AB70	13.23	8	8	29	
260	581	PHC300AB70	13.25	8	8	29	
261	580	PHC300AB70	13.20	8	8	23	
262	579	PHC300AB70	13.22	8	8	28	
263	578	PHC300AB70	13.22	8	8	29	
264	577	PHC300AB70	13.20	8	8	29	
265	576	PHC300AB70	13.22	8	8	28	
266	575	PHC300AB70	13.21	8	8	29	
267	574	PHC300AB70	13.19	8	8	26	
268	573	PHC300AB70	13.23	8	8	28	
269	572	PHC300AB70	13.22	8	8	27	
270	571	PHC300AB70	13.23	8	8	29	
271	570	PHC300AB70	13.22	8	8	25	
272	569	PHC300AB70	13.23	8	8	29	
273	568	PHC300AB70	13.20	8	8	24	
274	567	PHC300AB70	13.19	8	8	28	
275	566	PHC300AB70	13.21	8	8	28	
276	565	PHC300AB70	13.20	8	8	29	
277	564	PHC300AB70	13.19	8	8	24	
278	563	PHC300AB70	13.21	8	8	26	
279	562	PHC300AB70	13.22	8	8	25	
280	561	PHC300AB70	13.25	8	8	24	
281	559	PHC300AB70	13.22	8	8	29	
282	537	PHC300AB70	13.22	8	8	24	
283	536	PHC300AB70	13.23	8	8	29	
284	535	PHC300AB70	13.21	8	8	24	
285	534	PHC300AB70	13.19	8	8	24	
286	533	PHC300AB70	13.17	8	8	29	
287	532	PHC300AB70	13.21	8	8	26	
288	531	PHC300AB70	13.22	8	8	24	
289	530	PHC300AB70	13.23	8	8	25	
290	529	PHC300AB70	13.21	8	8	24	
291	528	PHC300AB70	13.21	8	8	24	
292	527	PHC300AB70	13.22	8	8	25	
293	526	PHC300AB70	13.24	8	8	23	
294	525	PHC300AB70	13.23	8	8	24	
295	524	PHC300AB70	13.21	8	8	24	

旁站监理: 王云明

质检员: 李俊正

施工日期: 20170307