

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-08

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 5# ）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
296	523	PHC300AB70	13.25	8	8	27	
297	522	PHC300AB70	13.23	8	8	24	
298	521	PHC300AB70	13.21	8	8	25	
299	520	PHC300AB70	13.20	8	8	29	
300	519	PHC300AB70	13.21	8	8	24	
301	518	PHC300AB70	13.23	8	8	24	
302	516	PHC300AB70	13.30	8	8	23	
303	515	PHC300AB70	13.23	8	8	28	
304	514	PHC300AB70	13.23	8	8	29	
305	513	PHC300AB70	13.25	8	8	29	
306	512	PHC300AB70	13.22	8	8	23	
307	511	PHC300AB70	13.22	8	8	29	
308	510	PHC300AB70	13.23	8	8	29	
309	509	PHC300AB70	13.20	8	8	29	
310	508	PHC300AB70	13.22	8	8	28	
311	507	PHC300AB70	13.24	8	8	30	
312	506	PHC300AB70	13.19	8	8	26	
313	505	PHC300AB70	13.23	8	8	28	
314	504	PHC300AB70	13.22	8	8	27	
315	503	PHC300AB70	13.24	8	8	29	
316	502	PHC300AB70	13.23	8	8	25	
317	501	PHC300AB70	13.22	8	8	27	
318	500	PHC300AB70	13.22	8	8	24	
319	499	PHC300AB70	13.19	8	8	28	
320	498	PHC300AB70	13.21	8	8	28	
321	496	PHC300AB70	13.22	8	8	29	
322	495	PHC300AB70	13.19	8	8	26	
323	494	PHC300AB70	13.21	8	8	26	
324	493	PHC300AB70	13.23	8	8	25	
325	492	PHC300AB70	13.25	8	8	24	
326	491	PHC300AB70	13.24	8	8	29	
327	490	PHC300AB70	13.22	8	8	25	
328	489	PHC300AB70	13.23	8	8	29	
329	488	PHC300AB70	13.23	8	8	24	
330	487	PHC300AB70	13.19	8	8	24	
331	486	PHC300AB70	13.22	8	8	24	
332	485	PHC300AB70	13.19	8	8	28	
333	484	PHC300AB70	13.21	8	8	28	
334	483	PHC300AB70	13.22	8	8	29	
335	482	PHC300AB70	13.19	8	8	26	
336	481	PHC300AB70	13.21	8	8	26	
337	480	PHC300AB70	13.23	8	8	25	
338	479	PHC300AB70	13.25	8	8	24	
339	478	PHC300AB70	13.24	8	8	29	
340	477	PHC300AB70	13.22	8	8	25	

旁站监理:

王兴明

质检员:

李俊正

施工日期: 20170307