

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-09

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 5# ）		管桩型号	实际桩顶 标高（M）	使用桩长 （M）	有效桩长 （M）	最后贯入 度（MM）	备注
序号	桩号						
341	475	PHC300AB70	13.17	8	8	29	
342	453	PHC300AB70	13.18	8	8	27	
343	452	PHC300AB70	13.22	8	8	24	
344	451	PHC300AB70	13.23	8	8	25	
345	450	PHC300AB70	13.21	8	8	24	
346	449	PHC300AB70	13.19	8	8	24	
347	448	PHC300AB70	13.22	8	8	25	
348	447	PHC300AB70	13.24	8	8	23	
349	446	PHC300AB70	13.23	8	8	24	
350	445	PHC300AB70	13.19	8	8	25	
351	444	PHC300AB70	13.25	8	8	27	
352	443	PHC300AB70	13.24	8	8	24	
353	442	PHC300AB70	13.21	8	8	25	
354	441	PHC300AB70	13.24	8	8	29	
355	440	PHC300AB70	13.21	8	8	24	
356	439	PHC300AB70	13.24	8	8	24	
357	438	PHC300AB70	13.20	8	8	23	
358	437	PHC300AB70	13.23	8	8	28	
359	436	PHC300AB70	13.23	8	8	29	
360	435	PHC300AB70	13.25	8	8	29	
361	434	PHC300AB70	13.22	8	8	23	
362	432	PHC300AB70	13.20	8	8	29	
363	431	PHC300AB70	13.20	8	8	29	
364	430	PHC300AB70	13.20	8	8	29	
365	429	PHC300AB70	13.22	8	8	28	
366	428	PHC300AB70	13.24	8	8	30	
367	427	PHC300AB70	13.19	8	8	26	
368	426	PHC300AB70	13.23	8	8	28	
369	425	PHC300AB70	13.22	8	8	27	
370	424	PHC300AB70	13.24	8	8	29	
371	423	PHC300AB70	13.23	8	8	25	
372	422	PHC300AB70	13.22	8	8	27	
373	421	PHC300AB70	13.22	8	8	24	
374	420	PHC300AB70	13.19	8	8	28	
375	419	PHC300AB70	13.21	8	8	28	
376	417	PHC300AB70	13.22	8	8	29	
377	416	PHC300AB70	13.19	8	8	26	
378	415	PHC300AB70	13.21	8	8	26	
379	414	PHC300AB70	13.23	8	8	25	
380	413	PHC300AB70	13.25	8	8	24	
381	412	PHC300AB70	13.24	8	8	29	
382	411	PHC300AB70	13.22	8	8	25	
383	410	PHC300AB70	13.22	8	8	29	
384	409	PHC300AB70	13.23	8	8	24	
385	408	PHC300AB70	13.19	8	8	24	

旁站监理:

王兴明

质检员:

李俊正

施工日期: 20170308