

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-12

工程名称		通威渔光一体(东港)现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵 (5#)		管桩型号	实际桩顶标高 (M)	使用桩长 (M)	有效桩长 (M)	最后贯入度 (MM)	备注
序号	桩号						
476	258	PHC300AB70	13.21	8	8	30	
477	257	PHC300AB70	13.19	8	8	22	
478	256	PHC300AB70	13.23	8	8	28	
479	255	PHC300AB70	13.22	8	8	27	
480	254	PHC300AB70	13.24	8	8	29	
481	253	PHC300AB70	13.23	8	8	25	
482	252	PHC300AB70	13.22	8	8	28	
483	251	PHC300AB70	13.22	8	8	24	
484	250	PHC300AB70	13.19	8	8	28	
485	249	PHC300AB70	13.22	8	8	28	
486	248	PHC300AB70	13.22	8	8	30	
487	247	PHC300AB70	13.19	8	8	26	
488	246	PHC300AB70	13.21	8	8	26	
489	245	PHC300AB70	13.23	8	8	25	
490	243	PHC300AB70	13.25	8	8	28	
491	221	PHC300AB70	13.24	8	8	29	
492	220	PHC300AB70	13.22	8	8	25	
493	219	PHC300AB70	13.22	8	8	29	
494	218	PHC300AB70	13.23	8	8	27	
495	217	PHC300AB70	13.22	8	8	24	
496	216	PHC300AB70	13.17	8	8	29	
497	215	PHC300AB70	13.18	8	8	27	
498	214	PHC300AB70	13.22	8	8	25	
499	213	PHC300AB70	13.23	8	8	25	
500	212	PHC300AB70	13.21	8	8	27	
501	211	PHC300AB70	13.19	8	8	24	
502	210	PHC300AB70	13.24	8	8	25	
503	209	PHC300AB70	13.24	8	8	23	
504	208	PHC300AB70	13.23	8	8	27	
505	207	PHC300AB70	13.19	8	8	25	
506	206	PHC300AB70	13.22	8	8	23	
507	205	PHC300AB70	13.25	8	8	24	
508	204	PHC300AB70	13.21	8	8	25	
509	203	PHC300AB70	13.24	8	8	30	
510	202	PHC300AB70	13.25	8	8	26	
511	179	PHC300AB70	13.22	8	8	27	
512	178	PHC300AB70	13.20	8	8	23	
513	177	PHC300AB70	13.23	8	8	24	
514	176	PHC300AB70	13.24	8	8	29	
515	175	PHC300AB70	13.25	8	8	29	
516	174	PHC300AB70	13.23	8	8	23	
517	173	PHC300AB70	13.23	8	8	29	
518	172	PHC300AB70	13.21	8	8	29	
519	171	PHC300AB70	13.20	8	8	25	
520	170	PHC300AB70	13.18	8	8	28	

旁站监理:

王云明

质检员: 姜良正

施工日期: 20170309