

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-14

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 5# ）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
566	80	PHC300AB70	13.19	8	8	25	
567	79	PHC300AB70	13.23	8	8	29	
568	78	PHC300AB70	13.20	8	8	27	
569	77	PHC300AB70	13.22	8	8	29	
570	75	PHC300AB70	13.23	8	8	26	
571	74	PHC300AB70	13.22	8	8	28	
572	73	PHC300AB70	13.20	8	8	24	
573	72	PHC300AB70	13.19	8	8	25	
574	71	PHC300AB70	13.22	8	8	29	
575	70	PHC300AB70	13.22	8	8	30	
576	59	PHC300AB70	13.22	8	8	30	
577	58	PHC300AB70	13.19	8	8	26	
578	57	PHC300AB70	13.20	8	8	29	
579	56	PHC300AB70	13.23	8	8	25	
580	55	PHC300AB70	13.25	8	8	29	
581	53	PHC300AB70	13.25	8	8	29	
582	52	PHC300AB70	13.23	8	8	25	
583	51	PHC300AB70	13.22	8	8	29	
584	50	PHC300AB70	13.24	8	8	23	
585	49	PHC300AB70	13.22	8	8	24	
586	48	PHC300AB70	13.18	8	8	29	
587	47	PHC300AB70	13.19	8	8	29	
588	46	PHC300AB70	13.22	8	8	25	
589	45	PHC300AB70	13.23	8	8	28	
590	44	PHC300AB70	13.22	8	8	27	
591	43	PHC300AB70	13.19	8	8	24	
592	42	PHC300AB70	13.24	8	8	28	
593	41	PHC300AB70	13.24	8	8	23	
594	40	PHC300AB70	13.24	8	8	29	
595	39	PHC300AB70	13.19	8	8	25	
596	38	PHC300AB70	13.22	8	8	25	
597	37	PHC300AB70	13.25	8	8	24	
598	36	PHC300AB70	13.23	8	8	25	
599	35	PHC300AB70	13.25	8	8	30	
600	34	PHC300AB70	13.23	8	8	29	
601	10	PHC300AB70	13.23	8	8	29	
602	9	PHC300AB70	13.20	8	8	25	
603	8	PHC300AB70	13.21	8	8	24	
604	7	PHC300AB70	13.24	8	8	26	
605	6	PHC300AB70	13.23	8	8	29	
606	5	PHC300AB70	13.22	8	8	25	
607	4	PHC300AB70	13.23	8	8	30	
608	3	PHC300AB70	13.21	8	8	29	
609	2	PHC300AB70	13.22	8	8	25	
610	1	PHC300AB70	13.18	8	8	28	

旁站监理:

王兴明

质检员:

李成江

施工日期: 20170309