

混凝土预制桩施工监理旁站记录

编号：GFDZJBM30-GFQ-15

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 5# ）		管桩型号	实际桩顶 标高（M）	使用桩长 （M）	有效桩长 （M）	最后贯入 度（MM）	备注
序号	桩号						
611	箱变 1	PHC400A95	13.01	11	11	29	桩顶标高 13:00
612	箱变 2	PHC400A95	13.02	11	11	25	
613	箱变 3	PHC400A95	13.01	11	11	29	
614	箱变 4	PHC400A95	13.01	11	11	28	
615	箱变 5	PHC400A95	12.99	11	11	29	
616	箱变 6	PHC400A95	13.02	11	11	26	
617	264	PHC400A95	13.22	11	11	28	
618	266	PHC400A95	13.20	11	11	25	
619	267	PHC400A95	13.19	11	11	25	
620	268	PHC400A95	13.22	11	11	29	
621	269	PHC400A95	13.23	11	11	30	
622	270	PHC400A95	13.19	11	11	24	
623	271	PHC400A95	13.20	11	11	29	
624	272	PHC400A95	13.23	11	11	25	
625	273	PHC400A95	13.25	11	11	28	
626	274	PHC400A95	13.22	11	11	29	
627	191	PHC400A95	13.23	11	11	25	
628	192	PHC400A95	13.22	11	11	28	
629	193	PHC400A95	13.24	11	11	23	
630	194	PHC400A95	13.24	11	11	24	
631	195	PHC400A95	13.18	11	11	28	
632	196	PHC400A95	13.19	11	11	29	
633	197	PHC400A95	13.22	11	11	25	
634	198	PHC400A95	13.23	11	11	28	
635	199	PHC400A95	13.22	11	11	27	
636	200	PHC400A95	13.18	11	11	25	
637	180	PHC400A95	13.24	11	11	28	
638	182	PHC400A95	13.24	11	11	23	
639	183	PHC400A95	13.24	11	11	25	
640	184	PHC400A95	13.19	11	11	27	
641	185	PHC400A95	13.23	11	11	25	
642	186	PHC400A95	13.25	11	11	24	
643	187	PHC400A95	13.23	11	11	25	
644	188	PHC400A95	13.25	11	11	30	
645	189	PHC400A95	13.24	11	11	30	
646	190	PHC400A95	13.23	11	11	25	
647	107	PHC400A95	13.23	11	11	29	
648	108	PHC400A95	13.20	11	11	25	
649	109	PHC400A95	13.21	11	11	24	
650	110	PHC400A95	13.24	11	11	26	
651	111	PHC400A95	13.23	11	11	29	
652	112	PHC400A95	13.22	11	11	25	
653	113	PHC400A95	13.23	11	11	30	
654	114	PHC400A95	13.21	11	11	29	
655	115	PHC400A95	13.22	11	11	25	

旁站监理：王兴明

质检员：姜晓正

施工日期：20170310