

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-04

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 6# ）		管桩型号	实际桩顶 标高（M）	使用桩长 （M）	有效桩长 （M）	最后贯入 度（MM）	备注
序号	桩号						
136	410	PHC300A70	13.24	7	7	25	
137	411	PHC300A70	13.22	7	7	27	
138	412	PHC300A70	13.21	7	7	28	
139	413	PHC300A70	13.19	7	7	29	
140	414	PHC300A70	13.20	7	7	28	
141	416	PHC300A70	13.23	7	7	29	
142	417	PHC300A70	13.22	7	7	29	
143	418	PHC300A70	13.22	7	7	30	
144	419	PHC300A70	13.23	7	7	28	
145	420	PHC300A70	13.24	7	7	27	
146	421	PHC300A70	13.23	7	7	30	
147	422	PHC300A70	13.24	7	7	26	
148	423	PHC300A70	13.22	7	7	28	
149	424	PHC300A70	13.22	7	7	29	
150	457	PHC300A70	13.22	7	7	27	
151	458	PHC300A70	13.23	7	7	29	
152	459	PHC300A70	13.20	7	7	26	
153	460	PHC300A70	13.23	7	7	25	
154	461	PHC300A70	13.20	7	7	27	
155	462	PHC300A70	13.23	7	7	22	
156	463	PHC300A70	13.20	7	7	25	
157	464	PHC300A70	13.23	7	7	25	
158	465	PHC300A70	13.20	7	7	24	
159	466	PHC300A70	13.20	7	7	25	
160	467	PHC300A70	13.23	7	7	28	
161	468	PHC300A70	13.23	7	7	25	
162	469	PHC300A70	13.20	7	7	28	
163	470	PHC300A70	13.22	7	7	26	
164	471	PHC300A70	13.22	7	7	29	
165	395	PHC300A70	13.18	7	7	28	
166	268	PHC300A70	13.22	7	7	25	
167	267	PHC300A70	13.18	7	7	27	
168	266	PHC300A70	13.23	7	7	27	
169	265	PHC300A70	13.22	7	7	28	
170	263	PHC300A70	13.18	7	7	24	
171	262	PHC300A70	13.17	7	7	24	
172	261	PHC300A70	13.23	7	7	22	
173	260	PHC300A70	13.21	7	7	26	
174	259	PHC300A70	13.23	7	7	25	
175	258	PHC300A70	13.21	7	7	23	
176	257	PHC300A70	13.22	7	7	25	
177	256	PHC300A70	13.22	7	7	25	
178	255	PHC300A70	13.24	7	7	23	
179	254	PHC300A70	13.23	7	7	28	
180	252	PHC300A70	13.25	7	7	25	

旁站监理:

王宏明

质检员:

姜卫卫

施工日期: 20170310