

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-09

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 6# ）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
351	599	PHC300AB70	13.17	8	8	29	
352	600	PHC300AB70	13.18	8	8	27	
353	601	PHC300AB70	13.22	8	8	24	
354	602	PHC300AB70	13.23	8	8	25	
355	603	PHC300AB70	13.21	8	8	24	
356	588	PHC300AB70	13.19	8	8	24	
357	590	PHC300AB70	13.22	8	8	25	
358	591	PHC300AB70	13.24	8	8	23	
359	592	PHC300AB70	13.23	8	8	24	
360	593	PHC300AB70	13.19	8	8	25	
361	594	PHC300AB70	13.25	8	8	27	
362	595	PHC300AB70	13.24	8	8	24	
363	596	PHC300AB70	13.21	8	8	25	
364	597	PHC300AB70	13.24	8	8	29	
365	598	PHC300AB70	13.21	8	8	24	
366	525	PHC300AB70	13.24	8	8	24	
367	526	PHC300AB70	13.20	8	8	23	
368	527	PHC300AB70	13.23	8	8	28	
369	528	PHC300AB70	13.23	8	8	29	
370	529	PHC300AB70	13.25	8	8	29	
371	530	PHC300AB70	13.22	8	8	23	
372	531	PHC300AB70	13.20	8	8	29	
373	532	PHC300AB70	13.20	8	8	29	
374	533	PHC300AB70	13.20	8	8	29	
375	534	PHC300AB70	13.22	8	8	28	
376	509	PHC300AB70	13.24	8	8	30	
377	510	PHC300AB70	13.19	8	8	26	
378	511	PHC300AB70	13.23	8	8	28	
379	512	PHC300AB70	13.22	8	8	27	
380	513	PHC300AB70	13.24	8	8	29	
381	514	PHC300AB70	13.23	8	8	25	
382	516	PHC300AB70	13.22	8	8	27	
383	517	PHC300AB70	13.22	8	8	24	
384	518	PHC300AB70	13.19	8	8	28	
385	519	PHC300AB70	13.21	8	8	28	
386	520	PHC300AB70	13.22	8	8	29	
387	521	PHC300AB70	13.19	8	8	26	
388	522	PHC300AB70	13.21	8	8	26	
389	523	PHC300AB70	13.23	8	8	25	
390	524	PHC300AB70	13.25	8	8	24	
391	441	PHC300AB70	13.24	8	8	29	
392	442	PHC300AB70	13.22	8	8	25	
393	443	PHC300AB70	13.22	8	8	29	
394	444	PHC300AB70	13.23	8	8	24	
395	445	PHC300AB70	13.19	8	8	24	

旁站监理:

王云月

质检员: 姜传正

施工日期: 20170312