

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-10

工程名称		通威渔光一体(东港)现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵 (6#)		管桩型号	实际桩顶标高 (M)	使用桩长 (M)	有效桩长 (M)	最后贯入度 (MM)	备注
序号	桩号						
396	446	PHC300AB70	13.17	8	8	29	
397	447	PHC300AB70	13.18	8	8	27	
398	448	PHC300AB70	13.20	8	8	24	
399	449	PHC300AB70	13.20	8	8	25	
400	450	PHC300AB70	13.21	8	8	24	
401	451	PHC300AB70	13.19	8	8	24	
402	452	PHC300AB70	13.22	8	8	25	
403	453	PHC300AB70	13.24	8	8	23	
404	454	PHC300AB70	13.23	8	8	24	
405	455	PHC300AB70	13.19	8	8	25	
406	425	PHC300AB70	13.25	8	8	27	
407	426	PHC300AB70	13.24	8	8	24	
408	427	PHC300AB70	13.21	8	8	25	
409	428	PHC300AB70	13.24	8	8	29	
410	429	PHC300AB70	13.22	8	8	24	
411	430	PHC300AB70	13.23	8	8	24	
412	431	PHC300AB70	13.22	8	8	25	
413	432	PHC300AB70	13.22	8	8	23	
414	433	PHC300AB70	13.20	8	8	24	
415	434	PHC300AB70	13.21	8	8	25	
416	435	PHC300AB70	13.22	8	8	30	
417	437	PHC300AB70	13.19	8	8	26	
418	438	PHC300AB70	13.21	8	8	28	
419	439	PHC300AB70	13.23	8	8	27	
420	440	PHC300AB70	13.25	8	8	29	
421	367	PHC300AB70	13.24	8	8	25	
422	368	PHC300AB70	13.22	8	8	27	
423	369	PHC300AB70	13.22	8	8	24	
424	370	PHC300AB70	13.23	8	8	28	
425	371	PHC300AB70	13.19	8	8	28	
426	373	PHC300AB70	13.17	8	8	29	
427	374	PHC300AB70	13.18	8	8	26	
428	375	PHC300AB70	13.23	8	8	26	
429	376	PHC300AB70	13.21	8	8	25	
430	377	PHC300AB70	13.23	8	8	24	
431	378	PHC300AB70	13.22	8	8	24	
432	379	PHC300AB70	13.20	8	8	23	
433	380	PHC300AB70	13.23	8	8	28	
434	381	PHC300AB70	13.23	8	8	29	
435	382	PHC300AB70	13.25	8	8	29	
436	351	PHC300AB70	13.22	8	8	23	
437	352	PHC300AB70	13.23	8	8	29	
438	353	PHC300AB70	13.21	8	8	29	
439	354	PHC300AB70	13.20	8	8	29	
440	355	PHC300AB70	13.22	8	8	28	

旁站监理:

王兴明

质检员:

姜健正

施工日期: 20170312