

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-12

工程名称		通威渔光一体(东港)现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵(6#)		管桩型号	实际桩顶标高(M)	使用桩长(M)	有效桩长(M)	最后贯入度(MM)	备注
序号	桩号						
486	284	PHC300AB70	13.21	8	8	30	
487	285	PHC300AB70	13.19	8	8	22	
488	286	PHC300AB70	13.23	8	8	28	
489	287	PHC300AB70	13.22	8	8	27	
490	288	PHC300AB70	13.24	8	8	29	
491	289	PHC300AB70	13.23	8	8	25	
492	290	PHC300AB70	13.22	8	8	28	
493	291	PHC300AB70	13.22	8	8	24	
494	292	PHC300AB70	13.19	8	8	28	
495	293	PHC300AB70	13.22	8	8	28	
496	211	PHC300AB70	13.22	8	8	30	
497	212	PHC300AB70	13.19	8	8	26	
498	213	PHC300AB70	13.21	8	8	26	
499	214	PHC300AB70	13.23	8	8	25	
500	215	PHC300AB70	13.25	8	8	28	
501	216	PHC300AB70	13.24	8	8	29	
502	217	PHC300AB70	13.22	8	8	25	
503	218	PHC300AB70	13.22	8	8	29	
504	219	PHC300AB70	13.23	8	8	27	
505	220	PHC300AB70	13.22	8	8	24	
506	222	PHC300AB70	13.17	8	8	29	
507	223	PHC300AB70	13.18	8	8	27	
508	224	PHC300AB70	13.22	8	8	25	
509	225	PHC300AB70	13.23	8	8	25	
510	226	PHC300AB70	13.21	8	8	27	
511	227	PHC300AB70	13.19	8	8	24	
512	228	PHC300AB70	13.24	8	8	25	
513	229	PHC300AB70	13.24	8	8	23	
514	230	PHC300AB70	13.23	8	8	27	
515	231	PHC300AB70	13.19	8	8	25	
516	232	PHC300AB70	13.22	8	8	23	
517	233	PHC300AB70	13.25	8	8	24	
518	234	PHC300AB70	13.21	8	8	25	
519	235	PHC300AB70	13.24	8	8	30	
520	236	PHC300AB70	13.25	8	8	26	
521	185	PHC300AB70	13.22	8	8	27	
522	186	PHC300AB70	13.20	8	8	23	
523	187	PHC300AB70	13.23	8	8	24	
524	188	PHC300AB70	13.24	8	8	29	
525	189	PHC300AB70	13.25	8	8	29	
526	190	PHC300AB70	13.23	8	8	23	
527	191	PHC300AB70	13.23	8	8	29	
528	192	PHC300AB70	13.21	8	8	29	
529	193	PHC300AB70	13.20	8	8	25	
530	194	PHC300AB70	13.18	8	8	28	

旁站监理:

王明

质检员:

姜传正

施工日期: 20170313