

混凝土预制桩施工监理旁站记录

编号：GFDZJBM30-GFQ-15

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 6# ）		管桩型号	实际桩顶 标高（M）	使用桩长 （M）	有效桩长 （M）	最后贯入 度（MM）	备注
序号	桩号						
621	64	PHC300AB70	13.22	8	8	29	
622	65	PHC300AB70	13.19	8	8	25	
623	66	PHC300AB70	13.24	8	8	29	
624	67	PHC300AB70	13.20	8	8	28	
625	68	PHC300AB70	13.22	8	8	29	
626	69	PHC300AB70	13.24	8	8	26	
627	70	PHC300AB70	13.22	8	8	28	
628	71	PHC300AB70	13.20	8	8	25	
629	72	PHC300AB70	13.19	8	8	25	
630	73	PHC300AB70	13.22	8	8	29	
631	11	PHC300AB70	13.23	8	8	30	
632	13	PHC300AB70	13.19	8	8	24	
633	14	PHC300AB70	13.20	8	8	29	
634	15	PHC300AB70	13.23	8	8	25	
635	16	PHC300AB70	13.25	8	8	28	
636	17	PHC300AB70	13.22	8	8	29	
637	18	PHC300AB70	13.23	8	8	25	
638	19	PHC300AB70	13.22	8	8	28	
639	20	PHC300AB70	13.24	8	8	23	
640	21	PHC300AB70	13.24	8	8	24	
641	22	PHC300AB70	13.18	8	8	28	
642	23	PHC300AB70	13.19	8	8	29	
643	24	PHC300AB70	13.22	8	8	25	
644	25	PHC300AB70	13.23	8	8	28	
645	26	PHC300AB70	13.22	8	8	27	
646	27	PHC300AB70	13.18	8	8	25	
647	28	PHC300AB70	13.24	8	8	28	
648	29	PHC300AB70	13.24	8	8	23	
649	30	PHC300AB70	13.24	8	8	25	
650	31	PHC300AB70	13.19	8	8	27	
651	32	PHC300AB70	13.23	8	8	25	
652	34	PHC300AB70	13.25	8	8	24	
653	35	PHC300AB70	13.23	8	8	25	
654	36	PHC300AB70	13.25	8	8	30	
655	37	PHC300AB70	13.24	8	8	30	
656	38	PHC300AB70	13.23	8	8	25	
657	39	PHC300AB70	13.23	8	8	29	
658	40	PHC300AB70	13.20	8	8	25	
659	41	PHC300AB70	13.21	8	8	24	
660	42	PHC300AB70	13.24	8	8	26	
661	箱变 1	PHC300AB70	13.01	8	8	29	箱变 1~6 桩顶标高 13.00M
662	箱变 2	PHC300AB70	13.02	8	8	25	
663	箱变 3	PHC300AB70	13.01	8	8	30	
664	箱变 4	PHC300AB70	13.02	8	8	29	
665	箱变 5	PHC300AB70	13.01	8	8	25	

旁站监理：王兴明 质检员：姜俊正

施工日期：20170314