

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-02

工程名称		通威渔光一体(东港)现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵(7#)		管桩型号	实际桩顶标高(M)	使用桩长(M)	有效桩长(M)	最后贯入度(MM)	备注
序号	桩号						
46	46	PHC300AB70	13.21	8	8	28	
47	47	PHC300AB70	13.21	8	8	27	
48	48	PHC300AB70	13.24	8	8	28	
49	49	PHC300AB70	13.23	8	8	28	
50	50	PHC300AB70	13.22	8	8	28	
51	51	PHC300AB70	13.22	8	8	29	
52	52	PHC300AB70	13.24	8	8	25	
53	53	PHC300AB70	13.24	8	8	27	
54	54	PHC300AB70	13.21	8	8	27	
55	55	PHC300AB70	13.20	8	8	27	
56	56	PHC300AB70	13.23	8	8	26	
57	57	PHC300AB70	13.20	8	8	26	
58	58	PHC300AB70	13.20	8	8	25	
59	59	PHC300AB70	13.20	8	8	25	
60	60	PHC300AB70	13.22	8	8	22	
61	61	PHC300AB70	13.20	8	8	24	
62	62	PHC300AB70	13.22	8	8	23	
63	63	PHC300AB70	13.21	8	8	22	
64	64	PHC300AB70	13.20	8	8	23	
65	65	PHC300AB70	13.17	8	8	24	
66	66	PHC300AB70	13.19	8	8	25	
67	67	PHC300AB70	13.20	8	8	27	
68	68	PHC300AB70	13.22	8	8	28	
69	69	PHC300AB70	13.19	8	8	29	
70	70	PHC300AB70	13.19	8	8	29	
71	71	PHC300AB70	13.22	8	8	25	
72	72	PHC300AB70	13.18	8	8	27	
73	73	PHC300AB70	13.23	8	8	27	
74	74	PHC300AB70	13.19	8	8	26	
75	75	PHC300AB70	13.18	8	8	25	
76	76	PHC300AB70	13.17	8	8	24	
77	77	PHC300AB70	13.23	8	8	23	
78	78	PHC300AB70	13.21	8	8	23	
79	79	PHC300AB70	13.22	8	8	24	
80	80	PHC300AB70	13.22	8	8	23	
81	81	PHC300AB70	13.24	8	8	25	
82	82	PHC300AB70	13.22	8	8	25	
83	83	PHC300AB70	13.24	8	8	24	
84	84	PHC300AB70	13.21	8	8	25	
85	85	PHC300AB70	13.25	8	8	25	
86	86	PHC300AB70	13.22	8	8	27	
87	87	PHC300AB70	13.22	8	8	27	
88	88	PHC300AB70	13.22	8	8	25	
89	89	PHC300AB70	13.20	8	8	27	
90	90	PHC300AB70	13.22	8	8	22	

旁站监理:

王兴明

质检员:

李健正

施工日期: 20170315