

混凝土预制桩施工监理旁站记录

编号：GFDZJBM30-GFQ-03

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（7#）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
91	91	PHC300AB70	13.23	8	8	28	
92	92	PHC300AB70	13.21	8	8	29	
93	93	PHC300AB70	13.22	8	8	28	
94	94	PHC300AB70	13.23	8	8	28	
95	95	PHC300AB70	13.24	8	8	28	
96	96	PHC300AB70	13.22	8	8	29	
97	97	PHC300AB70	13.24	8	8	26	
98	98	PHC300AB70	13.22	8	8	27	
99	99	PHC300AB70	13.21	8	8	27	
100	100	PHC300AB70	13.22	8	8	27	
101	101	PHC300AB70	13.23	8	8	25	
102	102	PHC300AB70	13.20	8	8	26	
103	103	PHC300AB70	13.22	8	8	25	
104	104	PHC300AB70	13.20	8	8	26	
105	105	PHC300AB70	13.23	8	8	22	
106	106	PHC300AB70	13.20	8	8	24	
107	107	PHC300AB70	13.23	8	8	23	
108	108	PHC300AB70	13.21	8	8	22	
109	109	PHC300AB70	13.20	8	8	23	
110	110	PHC300AB70	13.17	8	8	24	
111	111	PHC300AB70	13.23	8	8	25	
112	112	PHC300AB70	13.20	8	8	28	
113	113	PHC300AB70	13.22	8	8	28	
114	114	PHC300AB70	13.19	8	8	29	
115	115	PHC300AB70	13.18	8	8	28	
116	116	PHC300AB70	13.22	8	8	25	
117	117	PHC300AB70	13.18	8	8	27	
118	118	PHC300AB70	13.23	8	8	27	
119	119	PHC300AB70	13.20	8	8	26	
120	120	PHC300AB70	13.18	8	8	26	
121	121	PHC300AB70	13.17	8	8	24	
122	122	PHC300AB70	13.25	8	8	23	
123	123	PHC300AB70	13.21	8	8	23	
124	124	PHC300AB70	13.22	8	8	25	
125	125	PHC300AB70	13.21	8	8	23	
126	126	PHC300AB70	13.24	8	8	25	
127	127	PHC300AB70	13.22	8	8	25	
128	128	PHC300AB70	13.24	8	8	24	
129	129	PHC300AB70	13.21	8	8	27	
130	130	PHC300AB70	13.25	8	8	25	
131	131	PHC300AB70	13.22	8	8	27	
132	132	PHC300AB70	13.23	8	8	27	
133	133	PHC300AB70	13.22	8	8	28	
134	134	PHC300AB70	13.20	8	8	27	
135	135	PHC300AB70	13.24	8	8	22	

旁站监理：王云月

质检员：姜卫平

施工日期：20170316