

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-09

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 7# ）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
347	365	PHC400A95	13.22	11	11	25	
348	364	PHC400A95	13.24	11	11	23	
349	363	PHC400A95	13.23	11	11	24	
350	362	PHC400A95	13.19	11	11	25	
351	361	PHC400A95	13.25	11	11	27	
352	360	PHC400A95	13.24	11	11	24	
353	359	PHC400A95	13.21	11	11	25	
354	358	PHC400A95	13.24	11	11	29	
355	357	PHC400A95	13.21	11	11	24	
356	356	PHC400A95	13.24	11	11	24	
357	355	PHC400A95	13.20	11	11	23	
358	354	PHC400A95	13.23	11	11	28	
359	353	PHC400A95	13.23	11	11	29	
360	352	PHC400A95	13.25	11	11	29	
361	351	PHC400A95	13.22	11	11	23	
362	420	PHC400A95	13.20	11	11	29	
363	419	PHC400A95	13.20	11	11	29	
364	418	PHC400A95	13.20	11	11	29	
365	417	PHC400A95	13.22	11	11	28	
366	416	PHC400A95	13.24	11	11	30	
367	415	PHC400A95	13.19	11	11	26	
368	414	PHC400A95	13.23	11	11	28	
369	413	PHC400A95	13.22	11	11	27	
370	412	PHC400A95	13.24	11	11	29	
371	411	PHC400A95	13.23	11	11	25	
372	410	PHC400A95	13.22	11	11	27	
373	409	PHC400A95	13.22	11	11	24	
374	408	PHC400A95	13.19	11	11	28	
375	407	PHC400A95	13.21	11	11	28	
376	406	PHC400A95	13.22	11	11	29	
377	405	PHC400A95	13.19	11	11	26	
378	404	PHC400A95	13.21	11	11	26	
379	403	PHC400A95	13.23	11	11	25	
380	402	PHC400A95	13.25	11	11	24	
381	401	PHC400A95	13.24	11	11	29	
382	440	PHC400A95	13.22	11	11	25	
383	439	PHC400A95	13.22	11	11	29	
384	438	PHC400A95	13.23	11	11	24	
385	437	PHC400A95	13.19	11	11	24	
386	436	PHC400A95	13.17	11	11	29	
387	435	PHC400A95	13.18	11	11	27	
388	434	PHC400A95	13.20	11	11	24	
389	433	PHC400A95	13.20	11	11	25	
390	432	PHC400A95	13.21	11	11	24	
391	431	PHC400A95	13.19	11	11	24	

旁站监理:

王学明

质检员:

姜佳正

施工日期: 20170416