

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-10

工程名称		通威渔光一体(东港)现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵 (7#)		管桩型号	实际桩顶标高 (M)	使用桩长 (M)	有效桩长 (M)	最后贯入度 (MM)	备注
序号	桩号						
392	430	PHC400A95	13.22	11	11	25	
393	429	PHC400A95	13.24	11	11	23	
394	428	PHC400A95	13.23	11	11	24	
395	427	PHC400A95	13.19	11	11	25	
396	426	PHC400A95	13.25	11	11	27	
397	425	PHC400A95	13.24	11	11	24	
398	424	PHC400A95	13.21	11	11	25	
399	423	PHC400A95	13.24	11	11	29	
400	422	PHC400A95	13.22	11	11	24	
401	421	PHC400A95	13.23	11	11	24	
402	500	PHC400A95	13.22	11	11	25	
403	499	PHC400A95	13.22	11	11	23	
404	498	PHC400A95	13.20	11	11	24	
405	497	PHC400A95	13.21	11	11	25	
406	496	PHC400A95	13.22	11	11	30	
407	495	PHC400A95	13.19	11	11	26	
408	494	PHC400A95	13.21	11	11	28	
409	493	PHC400A95	13.23	11	11	27	
410	492	PHC400A95	13.25	11	11	29	
411	491	PHC400A95	13.24	11	11	25	
412	490	PHC400A95	13.22	11	11	27	
413	489	PHC400A95	13.22	11	11	24	
414	488	PHC400A95	13.23	11	11	28	
415	487	PHC400A95	13.19	11	11	28	
416	486	PHC400A95	13.17	11	11	29	
417	485	PHC400A95	13.18	11	11	26	
418	484	PHC400A95	13.23	11	11	26	
419	483	PHC400A95	13.21	11	11	25	
420	482	PHC400A95	13.23	11	11	24	
421	481	PHC400A95	13.22	11	11	24	
422	52	PHC400A95	13.20	11	11	23	
423	519	PHC400A95	13.23	11	11	28	
424	518	PHC400A95	13.23	11	11	29	
425	517	PHC400A95	13.25	11	11	29	
426	516	PHC400A95	13.22	11	11	23	
427	515	PHC400A95	13.23	11	11	29	
428	514	PHC400A95	13.21	11	11	29	
429	513	PHC400A95	13.20	11	11	29	
430	512	PHC400A95	13.22	11	11	28	
431	511	PHC400A95	13.21	11	11	30	
432	510	PHC400A95	13.19	11	11	26	
433	509	PHC400A95	13.23	11	11	28	
434	508	PHC400A95	13.22	11	11	27	
435	507	PHC400A95	13.24	11	11	29	
436	506	PHC400A95	13.23	11	11	25	

旁站监理:

王学明

质检员:

李健正

施工日期: 20170417