

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-12

工程名称		通威渔光一体(东港)现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵(7#)		管桩型号	实际桩顶标高(M)	使用桩长(M)	有效桩长(M)	最后贯入度(MM)	备注
序号	桩号						
482	660	PHC400A95	13.22	11	11	28	
483	659	PHC400A95	13.22	11	11	24	
484	658	PHC400A95	13.19	11	11	28	
485	657	PHC400A95	13.22	11	11	28	
486	656	PHC400A95	13.22	11	11	30	
487	655	PHC400A95	13.19	11	11	26	
488	654	PHC400A95	13.21	11	11	26	
489	653	PHC400A95	13.23	11	11	25	
490	652	PHC400A95	13.25	11	11	28	
491	651	PHC400A95	13.24	11	11	29	
492	650	PHC400A95	13.22	11	11	25	
493	649	PHC400A95	13.22	11	11	29	
494	648	PHC400A95	13.23	11	11	27	
495	647	PHC400A95	13.22	11	11	24	
496	646	PHC400A95	13.17	11	11	29	
497	645	PHC400A95	13.18	11	11	27	
498	644	PHC400A95	13.22	11	11	25	
499	643	PHC400A95	13.23	11	11	25	
500	642	PHC400A95	13.21	11	11	27	
501	641	PHC400A95	13.19	11	11	24	
502	640	PHC400A95	13.24	11	11	25	
503	639	PHC400A95	13.24	11	11	23	
504	638	PHC400A95	13.23	11	11	27	
505	637	PHC400A95	13.19	11	11	25	
506	636	PHC400A95	13.22	11	11	23	
507	665	PHC400A95	13.25	11	11	24	
508	664	PHC400A95	13.21	11	11	25	
509	663	PHC400A95	13.24	11	11	30	
510	662	PHC400A95	13.25	11	11	26	
511	661	PHC400A95	13.22	11	11	27	
512	225	PHC400A95	13.20	11	11	23	
513	224	PHC400A95	13.23	11	11	24	
514	223	PHC400A95	13.24	11	11	29	
515	222	PHC400A95	13.25	11	11	29	
516	221	PHC400A95	13.23	10	10	23	
517	220	PHC400A95	13.23	10	10	29	
518	219	PHC400A95	13.21	10	10	29	
519	218	PHC400A95	13.20	10	10	25	
520	217	PHC400A95	13.18	10	10	28	
521	216	PHC400A95	13.21	10	10	30	
522	265	PHC400A95	13.19	10	10	22	
523	264	PHC400A95	13.23	10	10	29	
524	263	PHC400A95	13.22	10	10	27	
525	262	PHC400A95	13.22	10	10	29	
526	261	PHC400A95	13.23	10	10	25	

旁站监理:

王岩明

质检员:

姜世正

施工日期: 20170418