

混凝土预制桩施工监理旁站记录

编号: GPDZJBM30-GPQ-02

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（8#）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
46	656	PHC400A95	13.21	11	11	23	
47	657	PHC400A95	13.21	11	11	27	
48	658	PHC400A95	13.24	11	11	23	
49	659	PHC400A95	13.23	11	11	23	
50	660	PHC400A95	13.22	11	11	23	
51	661	PHC400A95	13.22	11	11	29	
52	662	PHC400A95	13.24	11	11	25	
53	663	PHC400A95	13.24	11	11	27	
54	664	PHC400A95	13.21	11	11	27	
55	665	PHC400A95	13.20	11	11	27	
56	666	PHC400A95	13.23	11	11	26	
57	667	PHC400A95	13.20	11	11	26	
58	668	PHC400A95	13.20	11	11	25	
59	669	PHC400A95	13.20	11	11	25	
60	670	PHC400A95	13.22	11	11	22	
61	671	PHC400A95	13.20	11	11	24	
62	672	PHC400A95	13.22	11	11	23	
63	673	PHC400A95	13.21	11	11	22	
64	674	PHC400A95	13.20	11	11	23	
65	675	PHC400A95	13.17	11	11	24	
66	676	PHC400A95	13.19	11	11	25	
67	677	PHC400A95	13.20	11	11	27	
68	678	PHC400A95	13.22	11	11	28	
69	679	PHC400A95	13.19	11	11	29	
70	680	PHC400A95	13.19	11	11	29	
71	601	PHC400A95	13.22	11	11	25	
72	602	PHC400A95	13.18	11	11	27	
73	603	PHC400A95	13.23	11	11	27	
74	604	PHC400A95	13.19	11	11	26	
75	605	PHC400A95	13.18	11	11	25	
76	606	PHC400A95	13.17	11	11	24	
77	607	PHC400A95	13.23	11	11	23	
78	608	PHC400A95	13.21	11	11	23	
79	609	PHC400A95	13.22	11	11	24	
80	610	PHC400A95	13.22	11	11	23	
81	611	PHC400A95	13.24	11	11	25	
82	612	PHC400A95	13.22	11	11	25	
83	613	PHC400A95	13.24	11	11	24	
84	614	PHC400A95	13.21	11	11	25	
85	615	PHC400A95	13.25	11	11	25	
86	616	PHC400A95	13.22	11	11	27	
87	617	PHC400A95	13.22	11	11	27	
88	618	PHC400A95	13.22	11	11	25	
89	619	PHC400A95	13.20	11	11	27	
90	620	PHC400A95	13.22	11	11	22	

旁站监理:

王兴明

质检员:

李俊升

施工日期: 20170319