

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-03

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（8#）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
91	621	PHC400A95	13.23	11	11	28	
92	622	PHC400A95	13.21	11	11	29	
93	623	PHC400A95	13.22	11	11	28	
94	624	PHC400A95	13.23	11	11	28	
95	625	PHC400A95	13.24	11	11	28	
96	626	PHC400A95	13.22	11	11	29	
97	627	PHC400A95	13.24	11	11	26	
98	628	PHC400A95	13.22	11	11	27	
99	629	PHC400A95	13.21	11	11	27	
100	630	PHC400A95	13.22	11	11	27	
101	631	PHC400A95	13.23	11	11	25	
102	632	PHC400A95	13.20	11	11	26	
103	633	PHC400A95	13.22	11	11	25	
104	634	PHC400A95	13.20	11	11	26	
105	635	PHC400A95	13.23	11	11	22	
106	566	PHC400A95	13.20	11	11	24	
107	567	PHC400A95	13.23	11	11	23	
108	568	PHC400A95	13.21	11	11	22	
109	569	PHC400A95	13.20	11	11	23	
110	570	PHC400A95	13.17	11	11	24	
111	571	PHC400A95	13.23	11	11	25	
112	572	PHC400A95	13.20	11	11	28	
113	573	PHC400A95	13.22	11	11	28	
114	574	PHC400A95	13.19	11	11	29	
115	575	PHC400A95	13.18	11	11	28	
116	576	PHC400A95	13.22	11	11	25	
117	577	PHC400A95	13.18	11	11	27	
118	578	PHC400A95	13.23	11	11	27	
119	579	PHC400A95	13.20	11	11	26	
120	580	PHC400A95	13.18	11	11	26	
121	581	PHC400A95	13.17	11	11	24	
122	582	PHC400A95	13.25	11	11	23	
123	583	PHC400A95	13.21	11	11	23	
124	584	PHC400A95	13.22	11	11	25	
125	585	PHC400A95	13.21	11	11	23	
126	586	PHC400A95	13.24	11	11	25	
127	587	PHC400A95	13.22	11	11	25	
128	588	PHC400A95	13.24	11	11	24	
129	589	PHC400A95	13.21	11	11	27	
130	590	PHC400A95	13.25	11	11	25	
131	591	PHC400A95	13.22	11	11	27	
132	592	PHC400A95	13.23	11	11	27	
133	593	PHC400A95	13.22	11	11	28	
134	594	PHC400A95	13.20	11	11	27	
135	595	PHC400A95	13.24	11	11	22	

旁站监理:

王兴明

质检员:

李俊正

施工日期: 20170319