

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-04

工程名称		通威渔光一体(东港)现代渔业产业园一期20MWp光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵(8#)		管桩型号	实际桩顶标高(M)	使用桩长(M)	有效桩长(M)	最后贯入度(MM)	备注
序号	桩号						
136	596	PHC400A95	13.24	11	11	25	
137	597	PHC400A95	13.22	11	11	27	
138	598	PHC400A95	13.21	11	11	28	
139	599	PHC400A95	13.19	11	11	29	
140	600	PHC400A95	13.20	11	11	28	
141	521	PHC400A95	13.23	11	11	29	
142	522	PHC400A95	13.22	11	11	29	
143	523	PHC400A95	13.22	11	11	30	
144	524	PHC400A95	13.23	11	11	28	
145	525	PHC400A95	13.24	11	11	27	
146	526	PHC400A95	13.23	11	11	30	
147	527	PHC400A95	13.24	11	11	26	
148	528	PHC400A95	13.22	11	11	28	
149	529	PHC400A95	13.22	11	11	29	
150	530	PHC400A95	13.22	11	11	27	
151	531	PHC400A95	13.23	11	11	29	
152	532	PHC400A95	13.20	11	11	26	
153	533	PHC400A95	13.23	11	11	25	
154	534	PHC400A95	13.20	11	11	27	
155	535	PHC400A95	13.23	11	11	22	
156	536	PHC400A95	13.20	11	11	25	
157	537	PHC400A95	13.23	11	11	25	
158	538	PHC400A95	13.20	11	11	24	
159	539	PHC400A95	13.20	11	11	25	
160	540	PHC400A95	13.23	11	11	28	
161	541	PHC400A95	13.22	11	11	27	
162	542	PHC400A95	13.25	11	11	27	
163	543	PHC400A95	13.22	11	11	28	
164	544	PHC400A95	13.20	11	11	29	
165	545	PHC400A95	13.22	11	11	23	
166	546	PHC400A95	13.24	11	11	29	
167	547	PHC400A95	13.22	11	11	23	
168	548	PHC400A95	13.24	11	11	30	
169	549	PHC400A95	13.23	11	11	28	
170	550	PHC400A95	13.25	11	11	29	
171	551	PHC400A95	13.23	11	11	30	
172	552	PHC400A95	13.21	11	11	28	
173	553	PHC400A95	13.22	11	11	28	
174	554	PHC400A95	13.19	11	11	29	
175	555	PHC400A95	13.22	11	11	27	
176	486	PHC400A95	13.23	11	11	23	
177	487	PHC400A95	13.18	11	11	26	
178	488	PHC400A95	13.23	11	11	25	
179	489	PHC400A95	13.24	11	11	27	
180	490	PHC400A95	13.23	11	11	30	

旁站监理:

王云月

质检员:

李任正

施工日期: 20170319