

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-08

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 8# ）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
316	331	PHC400A95	13.23	11	11	25	
317	332	PHC400A95	13.22	11	11	27	
318	333	PHC400A95	13.22	11	11	24	
319	334	PHC400A95	13.19	11	11	28	
320	335	PHC400A95	13.21	11	11	28	
321	336	PHC400A95	13.22	11	11	29	
322	337	PHC400A95	13.19	11	11	26	
323	338	PHC400A95	13.21	11	11	26	
324	339	PHC400A95	13.23	11	11	25	
325	340	PHC400A95	13.25	11	11	24	
326	341	PHC400A95	13.24	11	11	29	
327	342	PHC400A95	13.22	11	11	25	
328	343	PHC400A95	13.23	11	11	29	
329	344	PHC400A95	13.23	11	11	24	
330	345	PHC400A95	13.19	11	11	24	
331	346	PHC400A95	13.22	11	11	24	
332	347	PHC400A95	13.19	11	11	28	
333	348	PHC400A95	13.21	11	11	28	
334	349	PHC400A95	13.22	11	11	29	
335	350	PHC400A95	13.19	11	11	26	
336	351	PHC400A95	13.21	11	11	26	
337	352	PHC400A95	13.23	11	11	25	
338	353	PHC400A95	13.25	11	11	24	
339	354	PHC400A95	13.24	11	11	29	
340	355	PHC400A95	13.22	11	11	25	
341	356	PHC400A95	13.17	11	11	29	
342	357	PHC400A95	13.18	11	11	27	
343	358	PHC400A95	13.22	11	11	24	
344	359	PHC400A95	13.23	11	11	25	
345	360	PHC400A95	13.21	11	11	24	
346	361	PHC400A95	13.19	11	11	24	
347	362	PHC400A95	13.22	11	11	25	
348	363	PHC400A95	13.24	11	11	23	
349	364	PHC400A95	13.23	11	11	24	
350	365	PHC400A95	13.19	11	11	25	
351	296	PHC400A95	13.25	11	11	27	
352	297	PHC400A95	13.24	11	11	24	
353	298	PHC400A95	13.21	11	11	25	
354	299	PHC400A95	13.24	11	11	29	
355	300	PHC400A95	13.21	11	11	24	
356	301	PHC400A95	13.24	11	11	24	
357	302	PHC400A95	13.20	11	11	23	
358	303	PHC400A95	13.23	11	11	28	
359	304	PHC400A95	13.23	11	11	29	
360	305	PHC400A95	13.25	11	11	29	

旁站监理:

王云明

质检员:

姜建正

施工日期: 20170321