

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-09

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 8# ）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
361	306	PHC400A95	13.22	11	11	23	
362	307	PHC400A95	13.20	11	11	29	
363	308	PHC400A95	13.20	11	11	29	
364	309	PHC400A95	13.20	11	11	29	
365	310	PHC400A95	13.22	11	11	28	
366	311	PHC400A95	13.24	11	11	30	
367	312	PHC400A95	13.19	11	11	26	
368	313	PHC400A95	13.23	11	11	28	
369	314	PHC400A95	13.22	11	11	27	
370	315	PHC400A95	13.24	11	11	29	
371	316	PHC400A95	13.23	11	11	25	
372	317	PHC400A95	13.22	11	11	27	
373	318	PHC400A95	13.22	11	11	24	
374	319	PHC400A95	13.19	11	11	28	
375	320	PHC400A95	13.21	11	11	28	
376	321	PHC400A95	13.22	11	11	29	
377	322	PHC400A95	13.19	11	11	26	
378	323	PHC400A95	13.21	11	11	26	
379	324	PHC400A95	13.23	11	11	25	
380	325	PHC400A95	13.25	11	11	24	
381	326	PHC400A95	13.24	11	11	29	
382	327	PHC400A95	13.22	11	11	25	
383	328	PHC400A95	13.22	11	11	29	
384	329	PHC400A95	13.23	11	11	24	
385	330	PHC400A95	13.19	11	11	24	
386	261	PHC400A95	13.17	11	11	29	
387	262	PHC400A95	13.18	11	11	27	
388	263	PHC400A95	13.20	11	11	24	
389	264	PHC400A95	13.20	11	11	25	
390	265	PHC400A95	13.21	11	11	24	
391	266	PHC400A95	13.19	11	11	24	
392	267	PHC400A95	13.22	11	11	25	
393	268	PHC400A95	13.24	11	11	23	
394	269	PHC400A95	13.23	11	11	24	
395	270	PHC400A95	13.19	11	11	25	
396	271	PHC400A95	13.25	11	11	27	
397	272	PHC400A95	13.24	11	11	24	
398	273	PHC400A95	13.21	11	11	25	
399	274	PHC400A95	13.24	11	11	29	
400	275	PHC400A95	13.22	11	11	24	
401	276	PHC400A95	13.23	11	11	24	
402	277	PHC400A95	13.22	11	11	25	
403	278	PHC400A95	13.22	11	11	23	
404	279	PHC400A95	13.20	11	11	24	
405	280	PHC400A95	13.21	11	11	25	

旁站监理:

王云明

质检员:

李俊正

施工日期: 20170321