

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-10

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 8# ）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
406	281	PHC400A95	13.22	11	11	30	
407	282	PHC400A95	13.19	11	11	26	
408	283	PHC400A95	13.21	11	11	28	
409	284	PHC400A95	13.23	11	11	27	
410	285	PHC400A95	13.25	11	11	29	
411	286	PHC400A95	13.24	11	11	25	
412	287	PHC400A95	13.22	11	11	27	
413	288	PHC400A95	13.22	11	11	24	
414	289	PHC400A95	13.23	11	11	28	
415	290	PHC400A95	13.19	11	11	28	
416	291	PHC400A95	13.17	11	11	29	
417	292	PHC400A95	13.18	11	11	26	
418	293	PHC400A95	13.23	11	11	26	
419	294	PHC400A95	13.21	11	11	25	
420	295	PHC400A95	13.23	11	11	24	
421	221	PHC400A95	13.22	11	11	24	
422	222	PHC400A95	13.20	11	11	23	
423	223	PHC400A95	13.23	11	11	28	
424	224	PHC400A95	13.23	11	11	29	
425	225	PHC400A95	13.25	11	11	29	
426	226	PHC400A95	13.22	11	11	23	
427	227	PHC400A95	13.23	11	11	29	
428	228	PHC400A95	13.21	11	11	29	
429	229	PHC400A95	13.20	11	11	29	
430	230	PHC400A95	13.22	11	11	28	
431	231	PHC400A95	13.21	11	11	30	
432	232	PHC400A95	13.19	11	11	26	
433	233	PHC400A95	13.23	11	11	28	
434	234	PHC400A95	13.22	11	11	27	
435	235	PHC400A95	13.24	11	11	29	
436	236	PHC400A95	13.23	11	11	25	
437	237	PHC400A95	13.22	11	11	27	
438	238	PHC400A95	13.22	11	11	24	
439	239	PHC400A95	13.19	11	11	28	
440	240	PHC400A95	13.22	11	11	28	
441	241	PHC400A95	13.22	11	11	29	
442	242	PHC400A95	13.19	11	11	26	
443	243	PHC400A95	13.21	11	11	26	
444	244	PHC400A95	13.23	11	11	25	
445	245	PHC400A95	13.25	11	11	24	
446	246	PHC400A95	13.24	11	11	29	
447	247	PHC400A95	13.22	11	11	25	
448	248	PHC400A95	13.22	11	11	29	
449	249	PHC400A95	13.23	11	11	24	
450	250	PHC400A95	13.22	11	11	24	

旁站监理:

王志明

质检员:

李俊正

施工日期: 20170321