

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-13

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 8# ）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
541	101	PHC400A95	13.17	11	11	29	
542	102	PHC400A95	13.19	11	11	27	
543	103	PHC400A95	13.22	11	11	25	
544	104	PHC400A95	13.23	11	11	28	
545	105	PHC400A95	13.24	11	11	27	
546	106	PHC400A95	13.19	11	11	24	
547	107	PHC400A95	13.24	11	11	25	
548	108	PHC400A95	13.24	11	11	23	
549	109	PHC400A95	13.23	11	11	29	
550	110	PHC400A95	13.19	11	11	25	
551	111	PHC400A95	13.22	11	11	23	
552	112	PHC400A95	13.25	11	11	24	
553	113	PHC400A95	13.21	11	11	25	
554	114	PHC400A95	13.25	11	11	30	
555	115	PHC400A95	13.25	11	11	27	
556	116	PHC400A95	13.22	11	11	29	
557	117	PHC400A95	13.20	11	11	23	
558	118	PHC400A95	13.21	11	11	24	
559	119	PHC400A95	13.24	11	11	26	
560	120	PHC400A95	13.25	11	11	29	
561	121	PHC400A95	13.22	11	11	23	
562	122	PHC400A95	13.23	11	11	30	
563	123	PHC400A95	13.21	11	11	29	
564	124	PHC400A95	13.20	11	11	25	
565	125	PHC400A95	13.22	11	11	30	
566	126	PHC400A95	13.19	11	11	25	
567	127	PHC400A95	13.23	11	11	29	
568	128	PHC400A95	13.20	11	11	27	
569	129	PHC400A95	13.22	11	11	29	
570	130	PHC400A95	13.23	11	11	26	
571	131	PHC400A95	13.22	11	11	28	
572	132	PHC400A95	13.20	11	11	24	
573	133	PHC400A95	13.19	11	11	25	
574	134	PHC400A95	13.22	11	11	29	
575	135	PHC400A95	13.22	11	11	30	
576	136	PHC400A95	13.22	11	11	30	
577	137	PHC400A95	13.19	11	11	26	
578	138	PHC400A95	13.20	11	11	29	
579	139	PHC400A95	13.23	11	11	25	
580	140	PHC400A95	13.25	11	11	29	
581	61	PHC400A95	13.25	11	11	29	
582	62	PHC400A95	13.23	11	11	25	
583	63	PHC400A95	13.22	11	11	29	
584	64	PHC400A95	13.24	11	11	23	
585	65	PHC400A95	13.22	11	11	24	

旁站监理:

王云明

质检员:

李俊正

施工日期: 20170323