

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-14

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 8# ）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
586	66	PHC400A95	13.18	11	11	29	
587	67	PHC400A95	13.19	11	11	29	
588	68	PHC400A95	13.22	11	11	25	
589	69	PHC400A95	13.23	11	11	28	
590	70	PHC400A95	13.22	11	11	27	
591	71	PHC400A95	13.19	11	11	24	
592	72	PHC400A95	13.24	11	11	28	
593	73	PHC400A95	13.24	11	11	23	
594	74	PHC400A95	13.24	11	11	29	
595	75	PHC400A95	13.19	11	11	25	
596	76	PHC400A95	13.22	11	11	25	
597	77	PHC400A95	13.25	11	11	24	
598	78	PHC400A95	13.23	11	11	25	
599	79	PHC400A95	13.25	11	11	30	
600	80	PHC400A95	13.23	11	11	29	
601	81	PHC400A95	13.23	11	11	29	
602	82	PHC400A95	13.20	11	11	25	
603	83	PHC400A95	13.21	11	11	24	
604	84	PHC400A95	13.24	11	11	26	
605	85	PHC400A95	13.23	11	11	29	
606	86	PHC400A95	13.22	11	11	25	
607	87	PHC400A95	13.23	11	11	30	
608	88	PHC400A95	13.21	11	11	29	
609	89	PHC400A95	13.22	11	11	25	
610	90	PHC400A95	13.18	11	11	28	
611	91	PHC400A95	13.22	11	11	29	
612	92	PHC400A95	13.19	11	11	25	
613	93	PHC400A95	13.24	11	11	29	
614	94	PHC400A95	13.20	11	11	28	
615	95	PHC400A95	13.22	11	11	29	
616	96	PHC400A95	13.24	11	11	26	
617	97	PHC400A95	13.22	11	11	28	
618	98	PHC400A95	13.20	11	11	25	
619	99	PHC400A95	13.19	11	11	25	
620	100	PHC400A95	13.22	11	11	29	
621	21	PHC400A95	13.23	11	11	30	
622	22	PHC400A95	13.19	11	11	24	
623	23	PHC400A95	13.20	11	11	29	
624	24	PHC400A95	13.23	11	11	25	
625	25	PHC400A95	13.25	11	11	28	
626	26	PHC400A95	13.22	11	11	29	
627	27	PHC400A95	13.23	11	11	25	
628	28	PHC400A95	13.22	11	11	28	
629	29	PHC400A95	13.24	11	11	23	
630	30	PHC400A95	13.24	11	11	24	

旁站监理:

王兴明

质检员:

姜俊正

施工日期: 20170323