

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-02

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（9#）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
46	51	PHC400A95-11.0	13.21	11	11	24	
47	52	PHC400A95-11.0	13.21	11	11	27	
48	53	PHC400A95-11.0	13.24	11	11	28	
49	54	PHC400A95-11.0	13.23	11	11	27	
50	55	PHC400A95-11.0	13.22	11	11	27	
51	56	PHC400A95-11.0	13.22	11	11	26	
52	57	PHC400A95-11.0	13.24	11	11	27	
53	58	PHC400A95-11.0	13.24	11	11	27	
54	59	PHC400A95-11.0	13.21	11	11	31	
55	60	PHC400A95-11.0	13.20	11	11	27	
56	61	PHC400A95-11.0	13.23	11	11	29	
57	62	PHC400A95-11.0	13.22	11	11	27	
58	63	PHC400A95-11.0	13.20	11	11	27	
59	64	PHC400A95-11.0	13.18	11	11	28	
60	65	PHC400A95-11.0	13.22	11	11	27	
61	66	PHC400A95-11.0	13.20	11	11	27	
62	67	PHC400A95-11.0	13.22	11	11	27	
63	68	PHC400A95-11.0	13.21	11	11	26	
64	69	PHC400A95-11.0	13.20	11	11	27	
65	70	PHC400A95-11.0	13.17	11	11	29	
66	71	PHC400A95-11.0	13.19	11	11	27	
67	72	PHC400A95-11.0	13.20	11	11	27	
68	73	PHC400A95-11.0	13.22	11	11	28	
69	74	PHC400A95-11.0	13.19	11	11	27	
70	75	PHC400A95-11.0	13.19	11	11	27	
71	81	PHC400A95-11.0	13.22	11	11	30	
72	82	PHC400A95-11.0	13.18	11	11	27	
73	83	PHC400A95-11.0	13.23	11	11	27	
74	84	PHC400A95-11.0	13.19	11	11	32	
75	85	PHC400A95-11.0	13.18	11	11	27	
76	86	PHC400A95-11.0	13.17	11	11	27	
77	87	PHC400A95-11.0	13.23	11	11	27	
78	88	PHC400A95-11.0	13.21	11	11	27	
79	89	PHC400A95-11.0	13.22	11	11	28	
80	90	PHC400A95-11.0	13.22	11	11	27	
81	91	PHC400A95-11.0	13.24	11	11	27	
82	92	PHC400A95-11.0	13.22	11	11	27	
83	93	PHC400A95-11.0	13.24	11	11	24	
84	94	PHC400A95-11.0	13.21	11	11	27	
85	95	PHC400A95-11.0	13.25	11	11	27	
86	96	PHC400A95-11.0	13.22	11	11	26	
87	97	PHC400A95-11.0	13.22	11	11	27	
88	98	PHC400A95-11.0	13.22	11	11	29	
89	99	PHC400A95-11.0	13.20	11	11	27	
90	100	PHC400A95-11.0	13.22	11	11	25	

旁站监理:

王兴明

质检员:

姜健飞

施工日期: 20170320