

混凝土预制桩施工监理旁站记录

编号：GFDZJBM30-GFQ-07

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 9# ）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
188	213	PHC400A95-11.0	13.24	11	11	27	
189	214	PHC400A95-11.0	13.23	11	11	27	
190	215	PHC400A95-11.0	13.25	11	11	28	
191	216	PHC400A95-11.0	13.23	11	11	27	
192	217	PHC400A95-11.0	13.21	11	11	27	
193	218	PHC400A95-11.0	13.22	11	11	30	
194	219	PHC400A95-11.0	13.19	11	11	27	
195	220	PHC400A95-11.0	13.22	11	11	27	
196	221	PHC400A95-11.0	13.23	11	11	32	
197	222	PHC400A95-11.0	13.18	11	11	27	
198	223	PHC400A95-11.0	13.23	11	11	27	
199	224	PHC400A95-11.0	13.24	11	11	27	
200	225	PHC400A95-11.0	13.23	11	11	27	
201	226	PHC400A95-11.0	13.19	11	11	28	
202	227	PHC400A95-11.0	13.23	11	11	27	
203	228	PHC400A95-11.0	13.20	11	11	27	
204	229	PHC400A95-11.0	13.19	11	11	27	
205	230	PHC400A95-11.0	13.23	11	11	24	
206	231	PHC400A95-11.0	13.23	11	11	27	
207	232	PHC400A95-11.0	13.19	11	11	28	
208	233	PHC400A95-11.0	13.22	11	11	27	
209	234	PHC400A95-11.0	13.22	11	11	27	
210	235	PHC400A95-11.0	13.19	11	11	30	
211	241	PHC400A95-11.0	13.22	11	11	27	
212	242	PHC400A95-11.0	13.20	11	11	27	
213	243	PHC400A95-11.0	13.23	11	11	32	
214	244	PHC400A95-11.0	13.20	11	11	27	
215	245	PHC400A95-11.0	13.18	11	11	27	
216	246	PHC400A95-11.0	13.17	11	11	27	
217	247	PHC400A95-11.0	13.20	11	11	27	
218	248	PHC400A95-11.0	13.21	11	11	28	
219	249	PHC400A95-11.0	13.23	11	11	27	
220	250	PHC400A95-11.0	13.21	11	11	27	
221	251	PHC400A95-11.0	13.24	11	11	27	
222	252	PHC400A95-11.0	13.22	11	11	24	
223	253	PHC400A95-11.0	13.24	11	11	27	

旁站监理：王兴明

质检员：李俊臣

施工日期：20170324