

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-11

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 9# ）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
267	272	PHC400A95-11.0	13.22	11	11	27	
268	273	PHC400A95-11.0	13.24	11	11	27	
269	274	PHC400A95-11.0	13.23	11	11	27	
270	275	PHC400A95-11.0	13.25	11	11	27	
271	281	PHC400A95-11.0	13.25	11	11	28	
272	282	PHC400A95-11.0	13.23	11	11	27	
273	283	PHC400A95-11.0	13.23	11	11	27	
274	284	PHC400A95-11.0	13.20	11	11	27	
275	285	PHC400A95-11.0	13.20	11	11	24	
276	286	PHC400A95-11.0	13.22	11	11	27	
277	287	PHC400A95-11.0	13.21	11	11	30	
278	288	PHC400A95-11.0	13.22	11	11	28	
279	289	PHC400A95-11.0	13.23	11	11	27	
280	290	PHC400A95-11.0	13.25	11	11	27	
281	291	PHC400A95-11.0	13.20	11	11	30	
282	292	PHC400A95-11.0	13.22	11	11	27	
283	293	PHC400A95-11.0	13.22	11	11	27	
284	294	PHC400A95-11.0	13.20	11	11	32	
285	295	PHC400A95-11.0	13.22	11	11	27	
286	296	PHC400A95-11.0	13.21	11	11	27	
287	297	PHC400A95-11.0	13.19	11	11	27	
288	298	PHC400A95-11.0	13.23	11	11	27	
289	299	PHC400A95-11.0	13.22	11	11	28	
290	300	PHC400A95-11.0	13.23	11	11	27	
291	301	PHC400A95-11.0	13.22	11	11	27	
292	302	PHC400A95-11.0	13.23	11	11	27	
293	303	PHC400A95-11.0	13.20	11	11	24	
294	304	PHC400A95-11.0	13.19	11	11	27	
295	305	PHC400A95-11.0	13.21	11	11	30	
296	316	PHC400A95-11.0	13.20	11	11	28	
297	317	PHC400A95-11.0	13.19	11	11	27	
298	318	PHC400A95-11.0	13.21	11	11	27	
299	319	PHC400A95-11.0	13.22	11	11	30	
300	320	PHC400A95-11.0	13.25	11	11	27	
301	321	PHC400A95-11.0	13.22	11	11	27	
302	322	PHC400A95-11.0	13.22	11	11	32	
303	323	PHC400A95-11.0	13.23	11	11	27	
304	324	PHC400A95-11.0	13.21	11	11	27	
305	325	PHC400A95-11.0	13.19	11	11	27	
306	326	PHC400A95-11.0	13.17	11	11	27	
307	327	PHC400A95-11.0	13.21	11	11	28	
308	328	PHC400A95-11.0	13.22	11	11	27	
309	329	PHC400A95-11.0	13.23	11	11	27	
310	330	PHC400A95-11.0	13.21	11	11	27	
311	331	PHC400A95-11.0	13.21	11	11	24	

旁站监理:

王兴明

质检员:

姜佳正

施工日期: 20170330