

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-19

| 工程名称      |     | 通威渔光一体(东港)现代渔业产业园一期 20MWp 光伏发电项目 |            | 施工单位     |          | 特变电工新疆新能源股份有限公司 |    |
|-----------|-----|----------------------------------|------------|----------|----------|-----------------|----|
| 桩机类型      |     | 高频锤                              |            | 设计桩顶标高   |          | 13.20M          |    |
| 方阵 ( 9# ) |     | 管桩型号                             | 实际桩顶标高 (M) | 使用桩长 (M) | 有效桩长 (M) | 最后贯入度 (MM)      | 备注 |
| 序号        | 桩号  |                                  |            |          |          |                 |    |
| 551       | 588 | PHC400A95-11.0                   | 13.17      | 11       | 11       | 28              |    |
| 552       | 589 | PHC400A95-11.0                   | 13.19      | 11       | 11       | 27              |    |
| 553       | 590 | PHC400A95-11.0                   | 13.22      | 11       | 11       | 27              |    |
| 554       | 591 | PHC400A95-11.0                   | 13.23      | 11       | 11       | 30              |    |
| 555       | 592 | PHC400A95-11.0                   | 13.24      | 11       | 11       | 27              |    |
| 556       | 593 | PHC400A95-11.0                   | 13.19      | 11       | 11       | 27              |    |
| 557       | 594 | PHC400A95-11.0                   | 13.24      | 11       | 11       | 32              |    |
| 558       | 541 | PHC400A95-11.0                   | 13.24      | 11       | 11       | 25              |    |
| 559       | 542 | PHC400A95-11.0                   | 13.23      | 11       | 11       | 27              |    |
| 560       | 543 | PHC400A95-11.0                   | 13.19      | 11       | 11       | 27              |    |
| 561       | 544 | PHC400A95-11.0                   | 13.22      | 11       | 11       | 32              |    |
| 562       | 545 | PHC400A95-11.0                   | 13.25      | 11       | 11       | 27              |    |
| 563       | 546 | PHC400A95-11.0                   | 13.21      | 11       | 11       | 30              |    |
| 564       | 547 | PHC400A95-11.0                   | 13.25      | 11       | 11       | 28              |    |
| 565       | 548 | PHC400A95-11.0                   | 13.25      | 11       | 11       | 27              |    |
| 566       | 549 | PHC400A95-11.0                   | 13.22      | 11       | 11       | 27              |    |
| 567       | 550 | PHC400A95-11.0                   | 13.20      | 11       | 11       | 30              |    |
| 568       | 551 | PHC400A95-11.0                   | 13.21      | 11       | 11       | 27              |    |
| 569       | 552 | PHC400A95-11.0                   | 13.24      | 11       | 11       | 27              |    |
| 570       | 553 | PHC400A95-11.0                   | 13.25      | 11       | 11       | 32              |    |
| 571       | 554 | PHC400A95-11.0                   | 13.22      | 11       | 11       | 25              |    |
| 572       | 555 | PHC400A95-11.0                   | 13.23      | 11       | 11       | 27              |    |
| 573       | 556 | PHC400A95-11.0                   | 13.21      | 11       | 11       | 30              |    |
| 574       | 557 | PHC400A95-11.0                   | 13.20      | 11       | 11       | 28              |    |
| 575       | 558 | PHC400A95-11.0                   | 13.18      | 11       | 11       | 27              |    |
| 576       | 559 | PHC400A95-11.0                   | 13.22      | 11       | 11       | 27              |    |
| 577       | 560 | PHC400A95-11.0                   | 13.19      | 11       | 11       | 30              |    |
| 578       | 561 | PHC400A95-11.0                   | 13.23      | 11       | 11       | 27              |    |
| 579       | 562 | PHC400A95-11.0                   | 13.20      | 11       | 11       | 27              |    |
| 580       | 563 | PHC400A95-11.0                   | 13.22      | 11       | 11       | 32              |    |
| 581       | 564 | PHC400A95-11.0                   | 13.23      | 11       | 11       | 25              |    |
| 582       | 565 | PHC400A95-11.0                   | 13.22      | 11       | 11       | 27              |    |
| 583       | 501 | PHC400A95-11.0                   | 13.20      | 11       | 11       | 27              |    |
| 584       | 502 | PHC400A95-11.0                   | 13.19      | 11       | 11       | 32              |    |
| 585       | 503 | PHC400A95-11.0                   | 13.22      | 11       | 11       | 27              |    |
| 586       | 504 | PHC400A95-11.0                   | 13.22      | 11       | 11       | 30              |    |
| 587       | 505 | PHC400A95-11.0                   | 13.19      | 11       | 11       | 28              |    |
| 588       | 506 | PHC400A95-11.0                   | 13.20      | 11       | 11       | 27              |    |
| 589       | 507 | PHC400A95-11.0                   | 13.23      | 11       | 11       | 27              |    |
| 590       | 508 | PHC400A95-11.0                   | 13.25      | 11       | 11       | 30              |    |
|           |     |                                  |            |          |          |                 |    |
|           |     |                                  |            |          |          |                 |    |
|           |     |                                  |            |          |          |                 |    |
|           |     |                                  |            |          |          |                 |    |
|           |     |                                  |            |          |          |                 |    |

旁站监理: 王兴明

质检员: 姜佳臣

施工日期: 20170412