

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-03

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.2M	
方阵（ 10# ）		管桩型号	实际桩顶 标高（M）	使用桩长 （M）	有效桩长 （M）	最后贯入 度（MM）	备注
序号	桩号						
52	473	PHC400A95-12.0	13.24	12	12	27	
53	474	PHC400A95-12.0	13.24	12	12	27	
54	475	PHC400A95-12.0	13.24	12	12	31	
55	476	PHC400A95-12.0	13.20	12	12	27	
56	477	PHC400A95-12.0	13.23	12	12	29	
57	478	PHC400A95-12.0	13.22	12	12	27	
58	479	PHC400A95-12.0	13.20	12	12	27	
59	480	PHC400A95-12.0	13.18	12	12	28	
60	481	PHC400A95-12.0	13.22	12	12	27	
61	482	PHC400A95-12.0	13.20	12	12	27	
62	483	PHC400A95-12.0	13.22	12	12	27	
63	484	PHC400A95-12.0	13.21	12	12	26	
64	485	PHC400A95-12.0	13.20	12	12	27	
65	486	PHC400A95-12.0	13.17	12	12	29	
66	487	PHC400A95-12.0	13.19	12	12	27	
67	488	PHC400A95-12.0	13.20	12	12	27	
68	489	PHC400A95-12.0	13.22	12	12	28	
69	490	PHC400A95-12.0	13.19	12	12	27	
70	491	PHC400A95-12.0	13.19	12	12	27	
71	492	PHC400A95-12.0	13.22	12	12	30	
72	493	PHC400A95-12.0	13.18	12	12	27	
73	494	PHC400A95-12.0	13.23	12	12	27	
74	495	PHC400A95-12.0	13.19	12	12	32	
75	496	PHC400A95-12.0	13.18	12	12	27	
76	497	PHC400A95-12.0	13.17	12	12	27	
77	498	PHC400A95-12.0	13.23	12	12	27	
78	499	PHC400A95-12.0	13.21	12	12	27	
79	500	PHC400A95-12.0	13.22	12	12	28	
80	511	PHC400A95-12.0	13.22	12	12	27	
81	512	PHC400A95-12.0	13.24	12	12	27	
82	513	PHC400A95-12.0	13.22	12	12	27	
83	514	PHC400A95-12.0	13.24	12	12	24	
84	515	PHC400A95-12.0	13.21	12	12	27	
85	516	PHC400A95-12.0	13.25	12	12	27	
86	517	PHC400A95-12.0	13.22	12	12	26	
87	518	PHC400A95-12.0	13.22	12	12	27	
88	519	PHC400A95-12.0	13.22	12	12	29	
89	520	PHC400A95-12.0	13.20	12	12	27	
90	521	PHC400A95-12.0	13.22	12	12	25	
91	522	PHC400A95-12.0	13.23	12	12	26	
92	523	PHC400A95-12.0	13.21	12	12	27	
93	524	PHC400A95-12.0	13.22	12	12	28	
94	525	PHC400A95-12.0	13.23	12	12	27	
95	526	PHC400A95-12.0	13.24	12	12	28	
96	527	PHC400A95-12.0	13.22	12	12	26	

旁站监理:

王兴明

施工员:

李健臣

施工日期: 20170319