

混凝土预制桩施工监理旁站记录

编号：GFDZJBM30-GFQ-05

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（10#）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
125	561	PHC400A95-12.0	13.21	12	12	27	
126	562	PHC400A95-12.0	13.21	12	12	27	
127	563	PHC400A95-12.0	13.22	12	12	27	
128	564	PHC400A95-12.0	13.24	12	12	24	
129	565	PHC400A95-12.0	13.21	12	12	27	
130	566	PHC400A95-12.0	13.25	12	12	27	
131	567	PHC400A95-12.0	13.22	12	12	26	
132	568	PHC400A95-12.0	13.23	12	12	27	
133	569	PHC400A95-12.0	13.22	12	12	29	
134	570	PHC400A95-12.0	13.20	12	12	27	
135	571	PHC400A95-12.0	13.24	12	12	25	
136	572	PHC400A95-12.0	13.24	12	12	27	
137	573	PHC400A95-12.0	13.22	12	12	27	
138	574	PHC400A95-12.0	13.21	12	12	26	
139	575	PHC400A95-12.0	13.19	12	12	27	
140	576	PHC400A95-12.0	13.20	12	12	29	
141	577	PHC400A95-12.0	13.23	12	12	27	
142	578	PHC400A95-12.0	13.22	12	12	27	
143	579	PHC400A95-12.0	13.22	12	12	28	
144	580	PHC400A95-12.0	13.23	12	12	27	
145	586	PHC400A95-12.0	13.24	12	12	27	
146	587	PHC400A95-12.0	13.23	12	12	30	
147	588	PHC400A95-12.0	13.24	12	12	27	
148	589	PHC400A95-12.0	13.22	12	12	27	
149	590	PHC400A95-12.0	13.22	12	12	32	
150	591	PHC400A95-12.0	13.22	12	12	27	
151	592	PHC400A95-12.0	13.23	12	12	27	
152	593	PHC400A95-12.0	13.20	12	12	27	
153	594	PHC400A95-12.0	13.23	12	12	27	
154	595	PHC400A95-12.0	13.20	12	12	28	
155	596	PHC400A95-12.0	13.23	12	12	27	
156	597	PHC400A95-12.0	13.20	12	12	27	
157	598	PHC400A95-12.0	13.23	12	12	27	
158	599	PHC400A95-12.0	13.20	12	12	24	
159	600	PHC400A95-12.0	13.20	12	12	27	
160	601	PHC400A95-12.0	13.23	12	12	27	
161	602	PHC400A95-12.0	13.23	12	12	26	
162	603	PHC400A95-12.0	13.20	12	12	27	

旁站监理：

王兴明

施工员：

姜俊臣

施工日期：20170325