

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-19

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（10#）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
612	10	PHC400A95-12.0	13.20	12	12	25	
613	11	PHC400A95-12.0	13.21	12	12	27	
614	12	PHC400A95-12.0	13.24	12	12	30	
615	13	PHC400A95-12.0	13.23	12	12	28	
616	14	PHC400A95-12.0	13.22	12	12	27	
617	15	PHC400A95-12.0	13.23	12	12	27	
618	16	PHC400A95-12.0	13.21	12	12	30	
619	17	PHC400A95-12.0	13.22	12	12	27	
620	18	PHC400A95-12.0	13.18	12	12	27	
621	19	PHC400A95-12.0	13.22	12	12	32	
622	20	PHC400A95-12.0	13.19	12	12	25	
623	21	PHC400A95-12.0	13.24	12	12	27	
624	22	PHC400A95-12.0	13.20	12	12	27	
625	23	PHC400A95-12.0	13.22	12	12	32	
626	24	PHC400A95-12.0	13.24	12	12	27	
627	25	PHC400A95-12.0	13.22	12	12	30	
628	81	PHC400A95-12.0	13.20	12	12	28	
629	82	PHC400A95-12.0	13.19	12	12	27	
630	83	PHC400A95-12.0	13.22	12	12	27	
631	84	PHC400A95-12.0	13.23	12	12	30	
632	85	PHC400A95-12.0	13.19	12	12	27	
633	86	PHC400A95-12.0	13.20	12	12	32	
634	87	PHC400A95-12.0	13.23	12	12	27	
635	88	PHC400A95-12.0	13.25	12	12	30	
636	89	PHC400A95-12.0	13.22	12	12	25	
637	90	PHC400A95-12.0	13.23	12	12	27	
638	91	PHC400A95-12.0	13.22	12	12	27	
639	92	PHC400A95-12.0	13.24	12	12	32	
640	93	PHC400A95-12.0	13.24	12	12	27	
641	94	PHC400A95-12.0	13.18	12	12	30	
642	95	PHC400A95-12.0	13.19	12	12	28	
643	96	PHC400A95-12.0	13.22	12	12	27	
644	97	PHC400A95-12.0	13.23	12	12	27	
645	98	PHC400A95-12.0	13.22	12	12	30	
646	99	PHC400A95-12.0	13.18	12	12	27	
647	100	PHC400A95-12.0	13.24	12	12	32	
648	101	PHC400A95-12.0	13.24	12	12	27	
649	102	PHC400A95-12.0	13.24	12	12	30	
650	103	PHC400A95-12.0	13.19	12	12	25	
651	104	PHC400A95-12.0	13.23	12	12	27	
652	105	PHC400A95-12.0	13.25	12	12	27	
653	241	PHC400A95-12.0	13.23	12	12	32	
654	242	PHC400A95-12.0	13.25	12	12	27	
655	243	PHC400A95-12.0	13.24	12	12	30	
656	244	PHC400A95-12.0	13.23	12	12	28	

旁站监理:

王兴明

施工员:

姜健飞

施工日期: 20170414