

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-11

工程名称		通威渔光一体(东港)现代渔业产业园一期20MWp光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵(11#)		管桩型号	实际桩顶标高(M)	使用桩长(M)	有效桩长(M)	最后贯入度(MM)	备注
序号	桩号						
247	81	PHC400A95-12.0	13.23	12	12	32	
248	82	PHC400A95-12.0	13.20	12	12	30	
249	83	PHC400A95-12.0	13.19	12	12	27	
250	84	PHC400A95-12.0	13.21	12	12	29	
251	85	PHC400A95-12.0	13.23	12	12	27	
252	86	PHC400A95-12.0	13.19	12	12	32	
253	87	PHC400A95-12.0	13.21	12	12	30	
254	88	PHC400A95-12.0	13.22	12	12	27	
255	89	PHC400A95-12.0	13.19	12	12	32	
256	90	PHC400A95-12.0	13.22	12	12	30	
257	91	PHC400A95-12.0	13.21	12	12	27	
258	167	PHC400A95-12.0	13.23	12	12	32	
259	168	PHC400A95-12.0	13.21	12	12	32	
260	169	PHC400A95-12.0	13.18	12	12	30	
261	170	PHC400A95-12.0	13.17	12	12	27	
262	171	PHC400A95-12.0	13.21	12	12	29	
263	172	PHC400A95-12.0	13.21	12	12	27	
264	173	PHC400A95-12.0	13.23	12	12	32	
265	174	PHC400A95-12.0	13.21	12	12	30	
266	175	PHC400A95-12.0	13.24	12	12	27	
267	176	PHC400A95-12.0	13.22	12	12	32	
268	177	PHC400A95-12.0	13.24	12	12	30	
269	178	PHC400A95-12.0	13.23	12	12	27	
270	179	PHC400A95-12.0	13.25	12	12	32	
271	180	PHC400A95-12.0	13.25	12	12	32	
272	181	PHC400A95-12.0	13.23	12	12	30	
273	182	PHC400A95-12.0	13.23	12	12	27	
274	183	PHC400A95-12.0	13.20	12	12	29	
275	184	PHC400A95-12.0	13.20	12	12	27	
276	185	PHC400A95-12.0	13.22	12	12	32	
277	186	PHC400A95-12.0	13.21	12	12	30	
278	187	PHC400A95-12.0	13.22	12	12	27	
279	188	PHC400A95-12.0	13.23	12	12	32	
280	189	PHC400A95-12.0	13.25	12	12	30	
281	190	PHC400A95-12.0	13.20	12	12	27	
282	191	PHC400A95-12.0	13.22	12	12	32	
283	192	PHC400A95-12.0	13.22	12	12	32	
284	193	PHC400A95-12.0	13.20	12	12	30	
285	194	PHC400A95-12.0	13.22	12	12	27	
286	195	PHC400A95-12.0	13.21	12	12	29	
287	196	PHC400A95-12.0	13.19	12	12	27	
288	197	PHC400A95-12.0	13.23	12	12	32	
289	198	PHC400A95-12.0	13.22	12	12	30	
290	199	PHC400A95-12.0	13.23	12	12	27	
291	200	PHC400A95-12.0	13.22	12	12	32	

旁站监理:

王兴明

施工员:

姜佳飞

施工日期: 20170314