

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-04

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.2M	
方阵（ 12# ）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
59	91	PHC400A95-12.0	13.18	12	12	27	
60	149	PHC400A95-12.0	13.22	12	12	27	
61	150	PHC400A95-12.0	13.20	12	12	26	
62	151	PHC400A95-12.0	13.22	12	12	27	
63	152	PHC400A95-12.0	13.21	12	12	29	
64	153	PHC400A95-12.0	13.20	12	12	27	
65	154	PHC400A95-12.0	13.17	12	12	27	
66	155	PHC400A95-12.0	13.19	12	12	28	
67	156	PHC400A95-12.0	13.20	12	12	27	
68	157	PHC400A95-12.0	13.22	12	12	27	
69	158	PHC400A95-12.0	13.19	12	12	30	
70	159	PHC400A95-12.0	13.19	12	12	27	
71	160	PHC400A95-12.0	13.22	12	12	27	
72	161	PHC400A95-12.0	13.18	12	12	27	
73	162	PHC400A95-12.0	13.23	12	12	24	
74	163	PHC400A95-12.0	13.19	12	12	27	
75	164	PHC400A95-12.0	13.18	12	12	27	
76	165	PHC400A95-12.0	13.17	12	12	30	
77	166	PHC400A95-12.0	13.23	12	12	32	
78	167	PHC400A95-12.0	13.21	12	12	28	
79	168	PHC400A95-12.0	13.22	12	12	27	
80	169	PHC400A95-12.0	13.22	12	12	27	
81	170	PHC400A95-12.0	13.24	12	12	26	
82	171	PHC400A95-12.0	13.22	12	12	27	
83	176	PHC400A95-12.0	13.24	12	12	29	
84	177	PHC400A95-12.0	13.21	12	12	27	
85	178	PHC400A95-12.0	13.25	12	12	27	
86	179	PHC400A95-12.0	13.22	12	12	28	
87	180	PHC400A95-12.0	13.22	12	12	27	
88	181	PHC400A95-12.0	13.22	12	12	27	
89	182	PHC400A95-12.0	13.20	12	12	30	
90	183	PHC400A95-12.0	13.22	12	12	29	环裂
91	184	PHC400A95-12.0	13.23	12	12	27	
92	185	PHC400A95-12.0	13.21	12	12	27	
93	186	PHC400A95-12.0	13.22	12	12	28	
94	187	PHC400A95-12.0	13.23	12	12	27	
95	188	PHC400A95-12.0	13.24	12	12	29	
96	189	PHC400A95-12.0	13.22	12	12	27	
97	190	PHC400A95-12.0	13.24	12	12	27	
98	191	PHC400A95-12.0	13.22	12	12	28	
99	192	PHC400A95-12.0	13.21	12	12	27	
100	193	PHC400A95-12.0	13.22	12	12	27	
101	194	PHC400A95-12.0	13.23	12	12	30	
102	195	PHC400A95-12.0	13.20	12	12	29	
103	196	PHC400A95-12.0	13.22	12	12	27	

旁站监理: 王兴明

施工员: 李俊石

施工日期: 20170321