

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-06

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（12#）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
134	227	PHC400A95-12.0	13.20	12	12	27	
135	228	PHC400A95-12.0	13.24	12	12	27	
136	229	PHC400A95-12.0	13.24	12	12	28	
137	230	PHC400A95-12.0	13.22	12	12	27	
138	231	PHC400A95-12.0	13.21	12	12	27	
139	232	PHC400A95-12.0	13.19	12	12	30	
140	233	PHC400A95-12.0	13.20	12	12	29	
141	234	PHC400A95-12.0	13.23	12	12	27	
142	235	PHC400A95-12.0	13.22	12	12	27	
143	236	PHC400A95-12.0	13.22	12	12	28	
144	237	PHC400A95-12.0	13.23	12	12	27	
145	238	PHC400A95-12.0	13.24	12	12	27	
146	239	PHC400A95-12.0	13.23	12	12	30	
147	240	PHC400A95-12.0	13.24	12	12	29	
148	241	PHC400A95-12.0	13.22	12	12	27	
149	242	PHC400A95-12.0	13.22	12	12	28	
150	243	PHC400A95-12.0	13.22	12	12	27	
151	244	PHC400A95-12.0	13.23	12	12	27	
152	245	PHC400A95-12.0	13.20	12	12	30	
153	246	PHC400A95-12.0	13.23	12	12	29	
154	247	PHC400A95-12.0	13.20	12	12	27	
155	248	PHC400A95-12.0	13.23	12	12	27	
156	249	PHC400A95-12.0	13.20	12	12	28	
157	250	PHC400A95-12.0	13.23	12	12	27	
158	251	PHC400A95-12.0	13.20	12	12	27	
159	252	PHC400A95-12.0	13.20	12	12	30	
160	253	PHC400A95-12.0	13.23	12	12	29	
161	254	PHC400A95-12.0	13.23	12	12	27	
162	255	PHC400A95-12.0	13.20	12	12	28	
163	256	PHC400A95-12.0	13.22	12	12	27	
164	257	PHC400A95-12.0	13.22	12	12	27	
165	258	PHC400A95-12.0	13.18	12	12	30	
166	259	PHC400A95-12.0	13.22	12	12	29	
167	260	PHC400A95-12.0	13.18	12	12	27	
168	261	PHC400A95-12.0	13.23	12	12	27	
169	271	PHC400A95-12.0	13.22	12	12	28	
170	262	PHC400A95-12.0	13.18	12	12	27	
171	263	PHC400A95-12.0	13.17	12	12	27	
172	264	PHC400A95-12.0	13.23	12	12	30	
173	265	PHC400A95-12.0	13.21	12	12	29	
174	266	PHC400A95-12.0	13.23	12	12	27	
175	267	PHC400A95-12.0	13.21	12	12	27	
176	268	PHC400A95-12.0	13.22	12	12	28	
177	269	PHC400A95-12.0	13.22	12	12	27	
178	270	PHC400A95-12.0	13.24	12	12	27	

旁站监理:

王兴明

施工员:

姜健

施工日期: 20170322