

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-08

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（12#）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
224	337	PHC400A95-12.0	13.24	12	12	27	
225	338	PHC400A95-12.0	13.25	12	12	27	
226	339	PHC400A95-12.0	13.25	12	12	28	
227	340	PHC400A95-12.0	13.25	12	12	27	
228	341	PHC400A95-12.0	13.23	12	12	27	
229	342	PHC400A95-12.0	13.20	12	12	30	
230	343	PHC400A95-12.0	13.22	12	12	29	
231	344	PHC400A95-12.0	13.21	12	12	27	
232	345	PHC400A95-12.0	13.21	12	12	27	
233	346	PHC400A95-12.0	13.21	12	12	28	
234	347	PHC400A95-12.0	13.23	12	12	27	
235	348	PHC400A95-12.0	13.25	12	12	27	环裂
236	349	PHC400A95-12.0	13.23	12	12	30	
237	350	PHC400A95-12.0	13.22	12	12	29	
238	351	PHC400A95-12.0	13.22	12	12	27	
239	352	PHC400A95-12.0	13.19	12	12	28	
240	353	PHC400A95-12.0	13.22	12	12	27	
241	354	PHC400A95-12.0	13.21	12	12	27	
242	355	PHC400A95-12.0	13.18	12	12	30	
243	356	PHC400A95-12.0	13.23	12	12	29	
244	357	PHC400A95-12.0	13.21	12	12	27	
245	358	PHC400A95-12.0	13.23	12	12	27	
246	359	PHC400A95-12.0	13.21	12	12	28	
247	360	PHC400A95-12.0	13.23	12	12	27	
248	361	PHC400A95-12.0	13.20	12	12	27	
249	362	PHC400A95-12.0	13.19	12	12	30	
250	363	PHC400A95-12.0	13.21	12	12	29	
251	364	PHC400A95-12.0	13.23	12	12	27	
252	365	PHC400A95-12.0	13.19	12	12	28	
253	366	PHC400A95-12.0	13.21	12	12	27	
254	367	PHC400A95-12.0	13.22	12	12	27	
255	368	PHC400A95-12.0	13.19	12	12	30	
256	369	PHC400A95-12.0	13.22	12	12	29	
257	370	PHC400A95-12.0	13.21	12	12	27	
258	371	PHC400A95-12.0	13.23	12	12	27	
259	372	PHC400A95-12.0	13.21	12	12	28	
260	373	PHC400A95-12.0	13.18	12	12	27	
261	374	PHC400A95-12.0	13.17	12	12	27	
262	375	PHC400A95-12.0	13.21	12	12	30	
263	376	PHC400A95-12.0	13.21	12	12	29	
264	377	PHC400A95-12.0	13.23	12	12	27	
265	378	PHC400A95-12.0	13.21	12	12	27	
266	379	PHC400A95-12.0	13.24	12	12	28	
267	380	PHC400A95-12.0	13.22	12	12	27	
268	381	PHC400A95-12.0	13.24	12	12	27	

旁站监理:

王兴刚

施工员:

姜俊廷

施工日期: 20170322