

混凝土预制桩施工监理旁站记录

编号：GFDZJBM30-GFQ-09

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 12# ）		管桩型号	实际桩顶 标高（M）	使用桩长 （M）	有效桩长 （M）	最后贯入 度（MM）	备注
序号	桩号						
269	382	PHC400A95-12.0	13.23	12	12	27	
270	383	PHC400A95-12.0	13.25	12	12	27	
271	384	PHC400A95-12.0	13.25	12	12	28	
272	385	PHC400A95-12.0	13.23	12	12	27	
273	386	PHC400A95-12.0	13.23	12	12	27	
274	387	PHC400A95-12.0	13.20	12	12	30	
275	388	PHC400A95-12.0	13.20	12	12	29	
276	389	PHC400A95-12.0	13.22	12	12	27	
277	390	PHC400A95-12.0	13.21	12	12	27	
278	391	PHC400A95-12.0	13.22	12	12	28	
279	392	PHC400A95-12.0	13.23	12	12	27	
280	393	PHC400A95-12.0	13.25	12	12	27	
281	394	PHC400A95-12.0	13.20	12	12	30	
282	395	PHC400A95-12.0	13.22	12	12	29	
283	396	PHC400A95-12.0	13.22	12	12	27	
284	397	PHC400A95-12.0	13.20	12	12	28	
285	398	PHC400A95-12.0	13.22	12	12	27	
286	399	PHC400A95-12.0	13.21	12	12	27	