

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-03

工程名称		通威渔光一体(东港)现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.2M	
方阵 (13#)		管桩型号	实际桩顶标高 (M)	使用桩长 (M)	有效桩长 (M)	最后贯入度 (MM)	备注
序号	桩号						
71	71	PHC400A95-12.0	13.22	12	12	27	
72	72	PHC400A95-12.0	13.18	12	12	32	
73	73	PHC400A95-12.0	13.23	12	12	27	
74	74	PHC400A95-12.0	13.19	12	12	27	
75	75	PHC400A95-12.0	13.18	12	12	27	
76	76	PHC400A95-12.0	13.17	12	12	24	
77	77	PHC400A95-12.0	13.23	12	12	27	
78	78	PHC400A95-12.0	13.21	12	12	28	
79	79	PHC400A95-12.0	13.22	12	12	27	
80	80	PHC400A95-12.0	13.22	12	12	27	
81	81	PHC400A95-12.0	13.24	12	12	26	
82	82	PHC400A95-12.0	13.22	12	12	27	
83	83	PHC400A95-12.0	13.24	12	12	27	
84	84	PHC400A95-12.0	13.21	12	12	31	
85	85	PHC400A95-12.0	13.25	12	12	27	
86	86	PHC400A95-12.0	13.22	12	12	29	
87	87	PHC400A95-12.0	13.22	12	12	27	
88	88	PHC400A95-12.0	13.22	12	12	27	
89	89	PHC400A95-12.0	13.20	12	12	28	
90	90	PHC400A95-12.0	13.22	12	12	27	
91	91	PHC400A95-12.0	13.23	12	12	31	
92	92	PHC400A95-12.0	13.21	12	12	27	
93	93	PHC400A95-12.0	13.22	12	12	27	
94	94	PHC400A95-12.0	13.23	12	12	28	
95	95	PHC400A95-12.0	13.24	12	12	27	
96	96	PHC400A95-12.0	13.22	12	12	27	
97	97	PHC400A95-12.0	13.24	12	12	27	
98	98	PHC400A95-12.0	13.22	12	12	24	
99	99	PHC400A95-12.0	13.21	12	12	27	
100	100	PHC400A95-12.0	13.22	12	12	27	
101	101	PHC400A95-12.0	13.23	12	12	30	
102	102	PHC400A95-12.0	13.20	12	12	32	
103	103	PHC400A95-12.0	13.22	12	12	28	
104	104	PHC400A95-12.0	13.20	12	12	27	
105	105	PHC400A95-12.0	13.23	12	12	27	
106	121	PHC400A95-12.0	13.20	12	12	26	
107	122	PHC400A95-12.0	13.23	12	12	27	
108	123	PHC400A95-12.0	13.21	12	12	29	
109	124	PHC400A95-12.0	13.20	12	12	27	
110	125	PHC400A95-12.0	13.17	12	12	27	

旁站监理: 王兴明

施工员: 姜俊廷

施工日期: 20170324