

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-07

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 13# ）		管桩型号	实际桩顶 标高（M）	使用桩长 （M）	有效桩长 （M）	最后贯入 度（MM）	备注
序号	桩号						
208	516	PHC400A95-12.0	13.22	12	12	27	
209	517	PHC400A95-12.0	13.22	12	12	30	
210	518	PHC400A95-12.0	13.19	12	12	27	
211	519	PHC400A95-12.0	13.22	12	12	27	
212	520	PHC400A95-12.0	13.20	12	12	27	
213	521	PHC400A95-12.0	13.23	12	12	28	
214	522	PHC400A95-12.0	13.20	12	12	27	
215	523	PHC400A95-12.0	13.18	12	12	27	
216	541	PHC400A95-12.0	13.17	12	12	27	
217	542	PHC400A95-12.0	13.20	12	12	24	
218	543	PHC400A95-12.0	13.21	12	12	27	
219	544	PHC400A95-12.0	13.23	12	12	27	
220	545	PHC400A95-12.0	13.21	12	12	30	
221	546	PHC400A95-12.0	13.24	12	12	32	
222	547	PHC400A95-12.0	13.22	12	12	28	
223	548	PHC400A95-12.0	13.24	12	12	27	
224	549	PHC400A95-12.0	13.24	12	12	27	
225	550	PHC400A95-12.0	13.25	12	12	26	
226	551	PHC400A95-12.0	13.25	12	12	27	
227	552	PHC400A95-12.0	13.25	12	12	29	
228	553	PHC400A95-12.0	13.23	12	12	27	
229	554	PHC400A95-12.0	13.20	12	12	27	
230	555	PHC400A95-12.0	13.22	12	12	28	
231	556	PHC400A95-12.0	13.24	12	12	27	
232	557	PHC400A95-12.0	13.21	12	12	27	
233	558	PHC400A95-12.0	13.24	12	12	30	
234	559	PHC400A95-12.0	13.23	12	12	27	
235	560	PHC400A95-12.0	13.25	12	12	27	
236	561	PHC400A95-12.0	13.23	12	12	32	
237	562	PHC400A95-12.0	13.22	12	12	27	
238	563	PHC400A95-12.0	13.22	12	12	27	
239	564	PHC400A95-12.0	13.19	12	12	27	
240	565	PHC400A95-12.0	13.22	12	12	24	
241	566	PHC400A95-12.0	13.21	12	12	27	
242	567	PHC400A95-12.0	13.18	12	12	28	
243	568	PHC400A95-12.0	13.23	12	12	27	
244	569	PHC400A95-12.0	13.21	12	12	27	
245	570	PHC400A95-12.0	13.23	12	12	26	

旁站监理: 王兴明

施工员: 姜传正

施工日期: 20170329