

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-14

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.20M	
方阵（ 13# ）		管桩型号	实际桩顶 标高（M）	使用桩长 （M）	有效桩长 （M）	最后贯入 度（MM）	备注
序号	桩号						
456	161	PHC400A95-12.0	13.24	12	12	28	
457	162	PHC400A95-12.0	13.22	12	12	27	
458	163	PHC400A95-12.0	13.22	12	12	27	
459	164	PHC400A95-12.0	13.23	12	12	26	
460	165	PHC400A95-12.0	13.22	12	12	27	
461	166	PHC400A95-12.0	13.17	12	12	29	
462	167	PHC400A95-12.0	13.18	12	12	27	
463	168	PHC400A95-12.0	13.22	12	12	27	
464	169	PHC400A95-12.0	13.23	12	12	28	
465	170	PHC400A95-12.0	13.21	12	12	27	
466	171	PHC400A95-12.0	13.19	12	12	27	
467	172	PHC400A95-12.0	13.24	12	12	30	
468	173	PHC400A95-12.0	13.24	12	12	27	
469	174	PHC400A95-12.0	13.23	12	12	27	
470	175	PHC400A95-12.0	13.19	12	12	32	
471	176	PHC400A95-12.0	13.22	12	12	27	
472	177	PHC400A95-12.0	13.24	12	12	27	
473	178	PHC400A95-12.0	13.21	12	12	27	
474	179	PHC400A95-12.0	13.24	12	12	24	
475	180	PHC400A95-12.0	13.23	12	12	27	
476	181	PHC400A95-12.0	13.21	12	12	28	
477	182	PHC400A95-12.0	13.20	12	12	27	
478	183	PHC400A95-12.0	13.23	12	12	27	
479	184	PHC400A95-12.0	13.23	12	12	26	
480	185	PHC400A95-12.0	13.25	12	12	27	
481	186	PHC400A95-12.0	13.22	12	12	27	
482	187	PHC400A95-12.0	13.23	12	12	31	
483	188	PHC400A95-12.0	13.21	12	12	27	
484	189	PHC400A95-12.0	13.20	12	12	29	
485	190	PHC400A95-12.0	13.19	12	12	27	
486	191	PHC400A95-12.0	13.21	12	12	27	
487	192	PHC400A95-12.0	13.19	12	12	27	
488	193	PHC400A95-12.0	13.23	12	12	30	
489	194	PHC400A95-12.0	13.22	12	12	27	
490	195	PHC400A95-12.0	13.24	12	12	27	
491	196	PHC400A95-12.0	13.23	12	12	27	
492	197	PHC400A95-12.0	13.22	12	12	28	
493	198	PHC400A95-12.0	13.22	12	12	27	
494	199	PHC400A95-12.0	13.19	12	12	27	
495	200	PHC400A95-12.0	13.22	12	12	27	

旁站监理:

王兴明

施工员:

李传江

施工日期: 20170407