

混凝土预制桩施工监理旁站记录

编号: GFDZJBM30-GFQ-16

工程名称		通威渔光一体（东港）现代渔业产业园一期 20MWp 光伏发电项目		施工单位		特变电工新疆新能源股份有限公司	
桩机类型		高频锤		设计桩顶标高		13.2M	
方阵（ 13# ）		管桩型号	实际桩顶标高（M）	使用桩长（M）	有效桩长（M）	最后贯入度（MM）	备注
序号	桩号						
539	316	PHC400A95-12.0	13.19	12	12	27	
540	317	PHC400A95-12.0	13.22	12	12	27	
541	318	PHC400A95-12.0	13.22	12	12	24	
542	319	PHC400A95-12.0	13.19	12	12	27	
543	320	PHC400A95-12.0	13.21	12	12	27	
544	321	PHC400A95-12.0	13.23	12	12	30	
545	322	PHC400A95-12.0	13.25	12	12	32	
546	323	PHC400A95-12.0	13.25	12	12	28	
547	324	PHC400A95-12.0	13.22	12	12	27	
548	325	PHC400A95-12.0	13.22	12	12	27	
549	326	PHC400A95-12.0	13.24	12	12	26	
550	327	PHC400A95-12.0	13.22	12	12	27	
551	328	PHC400A95-12.0	13.17	12	12	29	
552	329	PHC400A95-12.0	13.19	12	12	27	
553	330	PHC400A95-12.0	13.22	12	12	27	
554	331	PHC400A95-12.0	13.23	12	12	28	
555	332	PHC400A95-12.0	13.24	12	12	27	
556	333	PHC400A95-12.0	13.19	12	12	27	
557	334	PHC400A95-12.0	13.24	12	12	30	
558	335	PHC400A95-12.0	13.24	12	12	27	
559	336	PHC400A95-12.0	13.23	12	12	27	
560	337	PHC400A95-12.0	13.19	12	12	32	
561	338	PHC400A95-12.0	13.22	12	12	27	
562	339	PHC400A95-12.0	13.25	12	12	27	
563	340	PHC400A95-12.0	13.21	12	12	27	
564	341	PHC400A95-12.0	13.25	12	12	24	
565	342	PHC400A95-12.0	13.25	12	12	27	
566	343	PHC400A95-12.0	13.22	12	12	28	
567	344	PHC400A95-12.0	13.20	12	12	27	
568	345	PHC400A95-12.0	13.21	12	12	27	
569	346	PHC400A95-12.0	13.24	12	12	26	
570	347	PHC400A95-12.0	13.25	12	12	27	
571	348	PHC400A95-12.0	13.22	12	12	27	
572	349	PHC400A95-12.0	13.23	12	12	31	
573	350	PHC400A95-12.0	13.21	12	12	27	
574	351	PHC400A95-12.0	13.20	12	12	29	
575	352	PHC400A95-12.0	13.18	12	12	27	
576	353	PHC400A95-12.0	13.22	12	12	27	
577	354	PHC400A95-12.0	13.19	12	12	27	
578	355	PHC400A95-12.0	13.23	12	12	30	
579	356	PHC400A95-12.0	13.20	12	12	27	
580	357	PHC400A95-12.0	13.22	12	12	27	
581	358	PHC400A95-12.0	13.23	12	12	27	
582	359	PHC400A95-12.0	13.22	12	12	28	
583	360	PHC400A95-12.0	13.20	12	12	27	

旁站监理:

王兴明

施工员:

李俊正

施工日期: 20170410